



C-33



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/School/WZ/2022/1148


Dated: 18 / 10 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Bal Vidyalaya**, located at **Moti Nagar, New Delhi – 110015**, comprised of 02 Blocks, BL-1 & BL-2 Ground + 1 upper floor each. The premises was inspected by the officer concerned by this department on 28/09/2022 in the presence of Sh. Kanwar Pal Singh (HOS) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have complied with fire prevention & fire safety requirements in accordance DOE Circular F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and the premises is fit for occupancy class “Educational” Group B with effect from 18 / 10 / 2022 for a period of three years subject to compliance of the condition mentioned below:-

Issued on 18 / 10 / 2022 at New Delhi.


(Atul Garg)
Director


17/10/2022

Copy to:

1. The Principal, Govt. Sarvodaya Bal Vidyalaya, located at Moti Nagar, New Delhi – 110015.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

2/12

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Bal Vidyalaya, located at Moti Nagar, New Delhi - 110015.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 28/09/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Sh. Kanwar Pal Singh (HOS)
9. Year of Construction : 2000 (As per previous insp. report dtd.- 31/03/2014)
10. Applicant's letter No. : Email dated 13/09/2022

* The Said School is comprised of 02 Blocks, BL-1 & BL-2 = Ground + 1 floor each.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/Cr No. 3298-3398 dated 01/03/2011 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 12m Provided 330cm Provided NA 	<ul style="list-style-type: none"> MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 10 nos. CO₂, ABC type ISI marked 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR

9/10

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA

16	Provision of Lifts.					
	• Pressurization of Lift Shaft	NA	NA	NA		
	• Pressurization of Lift lobby	NA	NA	NA		
	• Communication In lift Car	NA	NA	NA		
	• Fireman's Grounding Switch	NA	NA	NA		
	• Lift Signage	NA	NA	NA		
17	Standby power supply			NA	NA	NA
18	Refuge Area.					
	➤ Total Area	NA	NA	NA		
	➤ Location	NA	NA	NA		
19	Fire Control Room					
	• Detector System Panel	NA	NA	NA		
	• Flow Switch Panel	NA	NA	NA		
	• PA System Panel	NA	NA	NA		
	• Batter backup	NA	NA	NA		
	• Building Floor Plans	NA	NA	NA		
20	Special Fire Protection Systems for Protection of special Risks, if any:			NA	NA	NA

The fire protection system provided in the building was test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

335/ADO/MN
06/10/2022

Do (S/w)
11/10/22

Dy. Inspo (N2)
11/10/22

CFP
12/10/2022

Director
11/10/22

11/10/22

Signature
06/10/2022

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)