

C/35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / WZ / 1146

Dated: 18/10/2022

FIRE SAFETY CERTIFICATE

Certified that **Happy Child Modern Public School** located at **63/19, Sirasapur Road, Khara Garhi, Delhi-110082** comprised of Ground Floor only owned/occupied by **Happy Child Modern Public School** was issued FSC by this department vide letter No F6 /DFS/MS/School/2019/2295 dated 10.12.2019. The premises was inspected by the officer concerned of this department on 26.09.2022 in the presence of **Sh. Vijender Singh (Manager)**, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from 18/10/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 18/10/2022 at New Delhi

Yours faithfully


Dharampal Bhardwaj
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to :-

1. The Director, Education, Old Secretariat , Delhi.
2. The Principal, Happy Child Modern Public School, Khara Garhi, Delhi-82.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

- N/A
N
1. Name & address of the building : Happy Child Modern Public School, 63/19, Siraspur Road, Khara Garhi, Delhi-110082.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground Floor Only.
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/School/2019/2295 Dated-10/12/2019
 6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 7. Date of inspection : 26/09/2022
 8. Name of Inspecting Officer : ADO, R.K.Sinha
 9. Name and designation of officers
From the building side : Sh. Vijender Singh (Manager)
 10. Year of Construction : 2002
 11. Applicant's letter No. : E mail id , Dated-22/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1.00 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA



	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	NA	MR
5.	Fire Extinguishers <ul style="list-style-type: none"> Total numbers Types IS marking 	03 ABC Yes	06 ABC Yes	MR MR MR
6.	First-Aid Hose Reels <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants <ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA

M

	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

M

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOI circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the FSC issued vide letter no. F6/DFS/MS/School/2019/2295.

DO(BW)

30/09/2022

ADO(BW)
29/9/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW

Dy(fo(w2))

6/10/2022

~~ADO(BW)~~ F-T letter ni putup for sign phus

Dy(fo(w2))

17/10/22

ADO(BW)
10/10/22

ms/ll