

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/2022/SZ/ 1186

Dated: 21/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Amity International School**, located at M Block, Saket, New Delhi-110017 comprised of Basement, Ground + 04 upper floor, but this school is running upto 3rd floor of the building owned/occupied by Amity International School was issued FSC by this department vide letter no F6/DFS/MS/School/2017/SZ/1227 dated 12/08/2017. The premise was re-inspected by the officer concerned of this department on 12/10/2022 in the presence of Mr. Ashish Singh and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy **Group B "Education Building" (Basement, Ground plus three upper floor only)** with effect 21/10/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 21/10/2022 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. The Principal, Amity International School, located at M Block, Saket, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. The basement shall be used as per the provisions of BBL /NBC Part- IV
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."
8. The management submitted an undertaking that we will not use the 4th floor of the building without getting fire Safety Certificate from Delhi Fire Service.

 N/12

INSPECTION REPORT

1	Name & Address of the Building	Amity International School, M Block, Saket, New Delhi-110017		
2	Type of Occupancy	Education Building "Group-D"		
3	Building Comprised of	Basement, Ground + 4 upper floor (the management will not use the 4 th floor an undertaking Submitted)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/1227 dated 12/08/2017		
6	Fire Safety Directives Letter No	DOE Circular dated 17/01/2005		
7	Date of Inspection	12/10/2022		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ashish Singh		
10	Year of construction	1990-95 & 2018		
11	Applicant letter No.	Diary no. 4847 dated 26/08/2022		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	9 m	MR
		Required	5 m	MR
		-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	Required	03 nos	MR
		Required	04 nos	MR
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	Required	1.41m, 1.48m & 1.50m (iron)	MR(old case)
		Required	1.51m, 1.02m, 1.16 & 1.48m	MR(old case)
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	Required	03 Provided	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH	Exhaust fan Provided	MR
		12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Fire Extinguisher ISI marked	56Nos	MR
			ABC & CO ₂ -	MR
			Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	Hose reel	02 at each floor	MR

M-13

17 Status
18 Ref

	<ul style="list-style-type: none"> Length of hose-reel hose. Nozzle Diameter 		30 m	MR
			5 mm	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
8.	MOEFA	-N/A-	-N/A-	-N/A-
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	Required	100 mm	MR
		Required	02 no	MR
		Required	02 no	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Terrace Level 			
	➤ Discharge of pump.	Required	900 & 220 LPM	MR
	➤ Head of pump.	Required	54m & 34.5m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		Required	Provided	MR
		-N/A-	Provided	MR
		10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-

17	Standby Power Supply	-N/A-	-N/A-	-N/A-
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection. The School management submitted an undertaking that we will not use the 4th floor of the building without getting fire NOC from Delhi Fire Service.

Keeping in view of the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/1227 dated 12/08/2017, renewal under rule 35 (6) of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
 Signature of the Inspecting Officer
 Name : Sh. Rajesh Kumar
 Designation: ADO (BCP)

Dy. CFO (SZ)

[Handwritten initials]

[Handwritten signature]

As approved, F.T. letter is put up for your signature P.I.

[Handwritten signature]

[Handwritten signature]

[Signature]
 18/10/2022

M.S. *[Handwritten signature]*