

C-40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022/ 1167

Dated: 20/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Anubhav Public School** located at **57, Uttranchal Enclave, Gali No-2, Sant Nagar Burari, Delhi-84** comprised of Ground and 03 upper floors (**School is running at Ground & 02 upper floor only**) owned/ occupied by **Anubhav Public School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2019/School/1862 dated 26.09.2019**. The premise was re-inspected by the officer concerned of this department on **29.09.2022** in the presence of **Sh. Krishan Kr. Dixit (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy "**Group B Educational**" for **ground and 02 upper floors only** with effect from ~~.....~~ **20/10/22** for a period of three years, in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010:

Issued on ~~..~~ **20/10/22** at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250
etc

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Manager, Anubhav Public School located at 57, Uttranchal Enclave, Gali No-2 Sant Nagar Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/19

INSPECTION REPORT

Name & address of the building

Anubhav Public School at Uttranchal Enclave, Gali No- 2 Sant Nagar Burari,
Delhi-110084

Type of Occupancy

Educational

Composition of building

Ground & 3 upper floors **but school is running at ground +02 upper floors
Only & third floor used for residential purpose**

Type of Case

Renewal

Details of previous NOC

F6/DFS/MS 2019/School 1862 dated 26 09 2019

Fire Safety directives letter No

Nil

Date of inspection

29 09 2022

Name of the Inspecting Officers

ADO (RN)

Name and designation of officers
from the building side

: Mr. Krishan Kr Dixit (Manager)

Year of Construction

: 2006

Applicant's letter No

: Letter No APS/220/2022 dated 23 09 2022

Plot Area-300sqm

Covered Area 1000 sqm,

class rooms - 15nos,

students---350nos

Minimum Standards on fire prevention and fire safety U/R 33		Director of Education letter dated 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	05m	MR (old case)
	• Gate width	5m	02m	MR (old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1 50m	1 06m & 1 22m	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1 m	1m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	12nos	13nos	MR

Sp

	<ul style="list-style-type: none"> Types ISI marking 	ABC/Co2	ABC-13	MR	
		ISI Marked	Yes		
6	First-Aid Hose Reels.			MR	
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR	
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR	
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR	
7	Automatic fire detection and alarming system.			MR	
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA	
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA	
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA	
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA	
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA	
8	MOEFA	NA	NA	NA	
9	Public Address System.	NA	NA	NA	
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement 	NA	NA	NA	
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA	
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA	
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA	
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA	
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA	
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access 	NA	NA	NA	
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA	
		450 LPM	450 LPM	MR	
		40m	40m	MR	
		Require	Provided	MR	
		Require	Provided	MR	
	14	Captive Water Storage for fire fighting.			
		<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
		<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA

Op

Exit Signage	Required	Provided	MR
Provision of Lifts.			
• Pressurization of Lift Shaft	N/A	N/A	N/A
• Pressurization of Lift lobby	N/A	N/A	N/A
• Communication In lift Car	N/A	N/A	N/A
• Fireman's Grounding Switch	N/A	N/A	N/A
• Lift Signage	N/A	N/A	N/A
17 Standby power supply	N/A	N/A	N/A
18 Refuge Area.			
➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
19 Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Batter backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
20 Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1862 dated 26.09.2019.

~~DO (NW)~~ — ON LEAVE

~~DO (SW)~~

[Handwritten signature]

11/10/22

~~Dy. Insp. (WZ)~~

[Handwritten signature]
17/10/22

~~Asst. Insp. (R-N)~~

As approved, F.T. Letter is put up for your signature pl.

~~Dy. Insp. (WZ)~~

[Handwritten signature]
20/10/2022

WST cell

[Signature]
07/10/2022
Signature of the Inspecting Officer
Name - C.I. Meena
Designation - ADO/RN

[Signature]
19/10/2022