



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-C-23  
आ.सं.टी. -  
अग्नि - संरक्षण


No. F6/DFS/MS/School/WZ/2022/ 1163

Dated: 20/10/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **G. R. Memorial Sr. Sec. Public School** Located at **Shiv Ram Park, Nilothi More, Delhi-110041**, comprised of Ground + 03 Upper Floor each owned / occupied by **G. R. Memorial Sr. Sec. Public School** was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/2019/1684 dated 28.08.2019**. The said premise was re-inspected by the officer concerned of this department on 12.10.2022 in the presence of Sh. Jitender Singh Dahiya (Accountant) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E. Cr. No. 3298-3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 20/10/22 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010, printed below.

Issued on 20/10/22 at New Delhi by.

  
(Dharampall Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, G. R. Memorial Public School, Shiv Ram Park, Nilothi More, Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

N-13

1. Name and address of the building: **G.R.Memorial Sr. Sec. Public School** Located at **Shiv Ram Park, Nilothi More, Delhi-110041**
2. Type of Occupancy : Educational, Ground + 03 Upper floors
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/1684 Dated 28.08.2019
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01-03-2011
6. Date of inspection : 12.10.2022
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Jitender Singh Dahiya (Accountant)
9. Year of Construction : 1991
10. Applicant's letter No. : nil dated 03.10.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 28.08.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.37 m x 1 & 1.53 m x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	1.85 m	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Open to sky	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	20 nos.	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

He

M-M

6	First Aid Hose Reels				
	• Total numbers on each floor	01	Provided	MR	
	• Length of hose reel hose	30 m	Provided	MR	
	• Nozzle diameter	5 mm	Provided	MR	
7	Automatic fire detection and alarming system		NA	NA	
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8.	MOEFA	NA	NA	NA	
9.	Public Address System	NA	NA	NA	
10.	Automatic Sprinkler System		NA	NA	
	• Basements	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11.	Internal Hydrants:		NA	NA	
	• Size of riser/down- comer	NA	NA	NA	
	• Number of hydrants per floor	NA	NA	NA	
	• Hose Box	NA	NA	NA	
12.	Yard Hydrants		NA	NA	
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13.	Pumping Arrangements:				
	• Ground Level	NA	NA	NA	
	• Discharge of main pump	NA	NA	NA	
	➤ Head of main pump	NA	NA	NA	
	➤ Number of main pumps	NA	NA	NA	
	➤ Jockey pump out put	NA	NA	NA	
	➤ Jockey pump head	NA	NA	NA	
	➤ Standby Pump out put	NA	NA	NA	
	➤ Standby Pump Head	NA	NA	NA	
	➤ Auto Staring/Manual stopping	NA	NA	NA	
	➤ Pump House Access	NA	NA	NA	
	• Terrace level				
	➤ Discharge of pump	450 lpm	450 lpm	MR	
	➤ Head of the pump	40 m	Provided	MR	
➤ Power supply	Required	Provided	MR		
➤ Auto starting of pump	Required	Provided	MR		
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA	
	➤ Draw off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	Required	Provided	MR	
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR	
		Required	Provided	MR	
15	Exit Signage				
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA	NA	
	➤ Pressurization of lift lobby	NA	NA	NA	
	➤ Communication in lift Car	NA	NA	NA	
	➤ Fireman's Grounding Switch	NA	NA	NA	
	➤ Lift Signage	NA	NA	NA	
17.	Standby power supply	NA	NA	NA	
18.	Refuge Area				
	➤ Total area	NA	NA	NA	
	➤ Location	NA	NA	NA	
19.	Fire control room				

*[Handwritten signature]*

MR  
MR  
MR  
1

11-15

➤	Detector system panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2017/1684 Dated 28.08.2019 is recommended.

Accordingly DFA is put up for approval please.

*Aman Kumar Lathar*  
15/10/22  
Aman Kumar Lathar  
ADO (JWP)

*DO (SW)*  
*15/10/22*

*DFA (W2)*  
*17/10/22*

*ADO (JWP)*  
F.T. letter is put-up for signature P1,  
*19/10/22*

*DFA (W2)*  
*19/10/22*

*MS/MS*

*Aman Kumar Lathar*  
18/10/22  
ADO (JWP)