

C.M

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6 / DFS / MS / 2022/ School/WZ/ 1173

Dated: 20/10/22

**FIRE SAFETY CERTIFICATE**

Certified that **Kendriya Vidyalaya** located at **AFS, Bawana, Delhi-110039** comprised of **Ground+One upper floor** owned/occupied by **Kendriya Vidyalaya** was issued fire safety certificate **vide letter no. F-6/DFS/MS/School/2019/2022 dated-21/10/2019**. The premises was inspected by the officer concerned of this department on dated 11.10.2022 in the presence of Sh. Subhash Chander (Principal) and found that the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 01/03/2011** and that the building / premises is fit for occupancy of **Class B (Educational)** with effect from 20/10/22 for a period of **three years**, subject to the compliance of the conditions mentioned below.

Issued on 20.10.22..... at New Delhi

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Kendriya Vidyalaya, AFS Bawana, Delhi-110039.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building	: Kendriya Vidyalaya, AFS Bawana, Delhi-110039.
2. Type of Occupancy	: Educational
3. Building Comprised	: Ground + First Floor
4. Type of Case	: Renewal
5. Details of Previous NOC	: Letter No. F.6/DFS/MS/School/2019/2022 Dated-21/10/2019
6. Fire Safety directives letter No	: Dir of Edu. Cir dated 01.03.2011.
7. Date of inspection	: 11/10/2022
8. Name of Inspecting Officer	: ADO, R.K. Sinha
9. Name and designation of officers From the building side	: Sh. Subhash Chander (Principal)
10. Year of Construction	: 2003
11. Applicant's letter No.	: Nil, Dated-21/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			MR
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	NA
	• Width of internal road	NA	NA	
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			MR
	• Upper Floors	03	04	NA
	• Basements	NA	NA	MR
	b. Width of staircases	1.50 m	1.50 m × 2 1.40 m × 2	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	<b>Compartmentation</b>			NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			NA
	• Basements	30 a/c per hour	NA	NA

*Rs*

12 w/c per hour

Natural  
Ventilated

MR

		12 w/c per hour	Natural Ventilated	MR
• Upper floors				
5.	<b>Fire Extinguishers</b>			
• Total numbers	14	32	MR	
• Types	ABC	ABC/CO2	MR	
• IS marking	Yes	Yes	MR	
6.	<b>First-Aid Hose Reels</b>			
• Total numbers on each floor	NA	NA	NA	
• Length of hose reel hose	NA	NA	NA	
• Nozzle diameter	NA	NA	NA	
7.	<b>Automatic fire detection and alarming system</b>			
• Type of detectors	NA	NA	NA	
• Location of Main Panel	NA	NA	NA	
• Location of Repeater Panel	NA	NA	NA	
• Alternate source of power	NA	NA	NA	
• Hooters' Location	NA	NA	NA	
8.	<b>MCEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
• Basement	NA	NA	NA	
• Ground Floor	NA	NA	NA	
• Sprinkler above false ceiling	NA	NA	NA	
11.	<b>Internal Hydrants</b>			
• Size of riser/down-comer	NA	NA	NA	
• Number of hydrants per floor	NA	NA	NA	
• Hose Box	NA	NA	NA	
12.	<b>Yard Hydrants</b>			
• Total number of hydrants	NA	NA	NA	
• Hose Box	NA	NA	NA	
13.	<b>Pumping Arrangements</b>			
• Ground Level				
➢ Discharge of main Pump	NA	NA	NA	
➢ Head of Main pump	NA	NA	NA	
➢ Number of main pumps	NA	NA	NA	
➢ Jockey Pump out put	NA	NA	NA	
➢ Jockey pump head	NA	NA	NA	
➢ Standby Pump out put	NA	NA	NA	
➢ Standby Pump Head	NA	NA	NA	
➢ Auto Starting/Manual Stopping	NA	NA	NA	

*Handwritten mark*

	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA


*M*


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DFS/MS/School/2019/2022.

~~DO (B.W.) on leave~~

~~Dy CTO (W2)~~

  
17/10/22

  
ADO (B.W.)  
13/10/22

Signature of Inspecting Officer


Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~ADO/B.W.~~ F-T letter in put up for sign place

~~Dy CTO (W2)~~

  
19/10/22

  
ADO (B.W.)  
18/10/22

MS/ cell