

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / WZ / 1166

Dated: 20/10/22

FIRE SAFETY CERTIFICATE

Certified that the **Nigam Pratibha Co-ed School** located at **Ishwar Colony, Bawana, Delhi-110039** comprised of Ground and first floor owned/occupied by **Nigam Pratibha Co-ed School** was issued FSC by this department vide letter No F6 /DFS/MS/School/WZ/2019/1286 dated 17.06.2019. The premises was inspected by the officer concerned of this department on 11.10.2022 in the presence of **Sh. Sunil Datt (Principal)**, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from20.10.22... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on20.10.22... at New Delhi


(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to : -

1. The Director, Education, North MCD, Civic Center, New Delhi.
2. The Principal, Nigam Pratibha Co-ed School, Ishwar Colony, Bawana, Delhi-39.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

2-14

INSPECTION REPORT

Nigam Pratibha Co ed School(ID 1355005) , Ishwar Colony ,Bawana, Delhi 110039

Educational
Ground One upper floor
Renewal

Letter No 16/DI S/MS School/WZ/2019/1286 Dated 17/06/2019
Dir of Edu Cir 01/03/2011

11/10/2022

ADO R K Sinha

Sh. Sunil Datt (Principal)
2003

E. mail id. Dated-29/09/2022

- 1. Name & address of the building
- 2. Type of Occupancy
- 3. Building comprised
- 4. Type of Case
- 5. Details of Previous NOC
- 6. Fire Safety directives letter No
- 7. Date of inspection
- 8. Name of Inspecting Officer
- 9. Name and designation of officers From the building side
- 10. Year of Construction
- 11. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	02	02	MR
	b. Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	1.50 m	1.65 m x 2	MR
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1 m double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

Signature

N-15

	12 a/c per hour	Natural Ventilated	MR
• Upper floors			
5. Fire Extinguishers	08	08	MR
• Total numbers	ABC	ABC	MR
• Types	Yes	Yes	MR
• IS marking			
6. First-Aid Hose Reels	NA	NA	NA
• Total numbers on each floor	30 m	NA	NA
• Length of hose reel hose	5 mm	NA	NA
• Nozzle diameter			
7. Automatic fire detection and alarming system	NA	NA	NA
• Type of detectors	NA	NA	NA
• Location of Main Panel	NA	NA	NA
• Location of Repeater Panel	NA	NA	NA
• Alternate source of power	NA	NA	NA
• Hooters' Location	NA	NA	NA
8. MOEFA	NA	NA	NA
9. Public Address System	NA	NA	NA
10. Automatic Sprinkler System	NA	NA	NA
• Basement	NA	NA	NA
• Ground Floor	NA	NA	NA
• Sprinkler above false ceiling	NA	NA	NA
11. Internal Hydrants	NA	NA	NA
• Size of riser/down-comer	NA	NA	NA
• Number of hydrants per floor	NA	NA	NA
• Hose Box	NA	NA	NA
12. Yard Hydrants	NA	NA	NA
• Total number of hydrants	NA	NA	NA
• Hose Box	NA	NA	NA
13. Pumping Arrangements			
• Ground Level	NA	NA	NA
➤ Discharge of main Pump	NA	NA	NA
➤ Head of Main pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey Pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby Pump out put	NA	NA	NA
➤ Standby Pump Head	NA	NA	NA
➤ Auto Starting/Manual Stopping	NA	NA	NA

h

MR	➤ Pump House Access	NA	NA	NA
	• Terrace level			
MR	➤ Discharge of pump	NA	NA	NA
V	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

[Handwritten signature]

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOI circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2019/1286.

~~DOO (WZ) on leave~~

~~DY (WZ)~~

[Handwritten signature]
17/10/22

[Signature]
ADO (BW)
13/10/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW

~~ADO/BW~~ F.T letter in put up for sign file

~~DY (WZ)~~

[Handwritten signature]
19/10/22

[Signature]
ADO (BW)
18/10/22

ms/ cell