



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2022 / 1177

Dated: 21/10/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Nigam prathiba Vidyalaya** located at **Saraswati Vihar, D Block, New Delhi-110034**, comprised of 02 Blocks, BL-1 & BL-2, Ground + 1 upper floor each, was issued FSC vide letter No. F6/DFS/MS/SCHOOL/2019/1871 dated 27/09/2019. The premises was re-inspected by the officer concerned by this department on 07/10/2022 in the presence of Smt. Seema Malik and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance DOE Circular 17/01/2011/NBC - IV and found that the premises is fit for occupancy class "Educational" Group B with effect from 21/10/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below:-

Issued on 21/10/22 at New Delhi.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

**Copy to:**

1. The Principal, Nigam Prathiba Vidyalaya, located at Saraswati Vihar, D Block, New Delhi - 110034.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **The School authority has given undertaking they are not using 2<sup>nd</sup> floor of BL-2 for any Purpose.**

**INSPECTION REPORT**

1. Name & address of the building : Nigam Prathibha Vidyalaya located at Saraswati Vihar, D Block, New Delhi-110034.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2019/1871 dated 27/09/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 07/10/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Smt. Seema Malik
9. Year of Construction : 2006 (As per previous insp. report dtd.- 09/09/2019)
10. Applicant's letter No. : Email dated 16/09/2022

\* The School is comprised of 02 Blocks, Ground + 1 upper floor each.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	12m Provided	MR
	• Gate width	Accessible	330cm Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	04 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	BLK-1=1X1.85cm,1x1.30 cm,1x1.50 cm & BLK-2=1x1.50cm.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	1 m	Provided	MR (old case)
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	10 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

*JS*

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>	NA	NA	NA

**Provision of Lifts.**

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

**\* Note: - The School authority has given undertaking they are not using 2<sup>nd</sup> floor of BL-2 for any Purpose.**

The fire protection system provided in the building was test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules DOE Circular no. 3298-3398 dated 01/03/2011, the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2019/1871 dated 27/09/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Do (MN)*  
*288/ADO/MN*  
*17/10/2022*

*[Signature]*  
*17/10/22*

Signature of the Inspecting officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

*649/DO/WD*  
*17/10/2022*

*[Signature]*  
*17/10*

*DCR (W2)*

*[Signature]*  
*18/10/2022*

*AAO/MN*

*Sin. F. T is put up for your kind perusal &*

*Signature*

*plz. pass.*

*[Signature]*  
*19/10/22*

*Dy. CRO (W2)*

*[Signature]*  
*20/10/2022*

*MS/ cell*