

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/2022/School/ 1175

Dated: 21/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **St. Model Public School** located at **I-21, Mahendra Park, Near Adarsh Nagar, Delhi-110033** comprised of **Ground & 03 upper floor** owned/ occupied by **St. Model Public School** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/School/2019/2154 dated 15.11.2019**. The premises was re-inspected by the officer concerned of this department on **14.10.2022** in presence of **Sh. Harvinder Singh (President)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from **21/10/2022** for a period of **three years**, subject to compliance of the conditions mentioned below.

Issued on ... **21/10/2022** ... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi -110054.
2. The President, St. Model Public School located at I-21, Mahendra Park, Near Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building	St. Model Public School at E-21, Mahendra Park, Near Adarsh Nagar, Delhi-33
2. Type of Occupancy	Educational
3. Composition of building	Ground & 03 Upper floors only
4. Type of Case	Renewal
5. Details of previous NOC	F 6 D/S MS School 2019 2154 Dated 15.11.2019
6. Fire Safety directives letter No	Nil
7. Date of inspection	14.10.2022
8. Name of the Inspecting Officers	ADO (RN)
9. Name and designation of officers from the building side	Sh. Harvinder Singh (President)
10. Year of Construction	1980
11. Applicant's letter No	Letter No Nil & DFS Dairy No 6685 Dated- 12.10.2022

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> 02 NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<ul style="list-style-type: none"> 1.50m NA 	<ul style="list-style-type: none"> 1.50m & 1m NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtan Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	<ul style="list-style-type: none"> 12 a/c per hour 12 a/c per hour 	<ul style="list-style-type: none"> NA Natural Ventilated 	<ul style="list-style-type: none"> NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	05nos	06nos	MR

N/19

14
Capti

	<ul style="list-style-type: none"> Types ISI marking 	ABC/CO2	ABC-06	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30m 5mm	01 30m 5mm	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40m Required N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM 40m Provided NA	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR N/A

De

MK N Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 2154 dated 15.11.2019.

DO/NW — ON DIFF


DY CFO (WZ)


19/10/22


Signature of the Inspecting Officer
Name - C. I. Meena
Designation:- ADO/RN

~~ADD~~ / R.N

As approved, F.T. letter is setup for your signature pl.


20/10/2022