

L20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2022 / School / WZ / (171)

Dated: 20/10/22

FIRE SAFETY CERTIFICATE

Certified that **Vaid Pt. Khushi Ram Govt. SBV** located at **Nangal Thakran , Delhi-110039** comprised of **02 Blocks-Ground+ One upper floor** owned/occupied by **Vaid Pt. Khushi Ram Govt. SBV** was issued FSC by this department vide letter No F6/DFS/MS/School/2019/2158 dated 15.11.2019. The premises was inspected by the officer concerned of this department on 11.10.2022 in the presence of **Sh. Roop Narayan (In-Charge)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from20.10.22... for a period of **three years** and subject to compliance of the conditions mentioned below.

Issued on .20.10.22..at New Delhi, by

Yours faithfully


(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat , Delhi.
2. The Principal, Vaid Pt. Khushi Ram Govt. SBV, Nangal Thakran, Delhi-39.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building	V P K R Govt Sarvodaya Bal Vidyalaya, Nangal Thakran, Delhi 39
2. Type of Occupancy	Educational
3. Building Comprised	Two Blocks (Ground + First Floor)
4. Type of Case	Renewal
5. Details of Previous NOC	Letter No 16/D/S/MS School/2019/2158 Dated 15/11/2019
6. Fire Safety directives letter No	Dir of Edu Cir 01/03/2011
7. Date of inspection	11.10.2022
8. Name of Inspecting Officer	ADO. R K Sinha
9. Name and designation of officers from the building side	Sh. Roop Narayan (In-charge)
10. Year of Construction	2013
11. Applicant's letter No.	SBV/N/22/592 Dated-14/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	1.50 m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	1.10 m double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR



5.	Fire Extinguishers	08	15	MR
	• Total numbers	ABC/Co2	ABC/Co2	MR
	• Types	Yes	Yes	MR
	• IS marking			
6.	First-Aid Hose Reels	NA	NA	NA
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system	NA	NA	NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

Handwritten signature

MR
MR
MR
NA
NA
NA

- Terrace level
 - Discharge of pump NA NA NA
 - Head of the pump NA NA NA
 - Power Supply NA NA NA
 - Auto Starting of pump NA NA NA

14. **Captive Water Storage for fire fighting**

- Underground tank capacity
 - Draw-off connection NA NA NA
 - Fire service inlet NA NA NA
 - Access to tank NA NA NA
- Overhead Tank capacity NA NA NA

15. **Exit Signage.**

16. **Provision of Lifts.**

- Pressurization of Lift Shaft NA NA NA
- Pressurization of Lift lobby NA NA NA
- Communication In lift Car NA NA NA
- Fireman's Grounding Switch NA NA NA
- Lift Signage NA NA NA

17. **Standby power supply**

18. **Refuge Area.**

- Total Area NA NA NA
- Location NA NA NA

19. **Fire Control Room**

- Detector System Panel NA NA NA
- Flow Switch Panel NA NA NA
- PA System Panel NA NA NA
- Battery backup NA NA NA
- Building Floor Plans NA NA NA

20. **Special Fire Protection System for Protection of special Risks, if any:**

NA NA NA

Dr

N-18

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOI circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the Fire Safety Certificate issued vide letter no.F-6/DF'S/MS/School/2019/2158.

[Signature]
ADO (B.W.)
13/10/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~Do (B.W.) on leave.~~

~~Do (B.W.)~~

[Signature]
17/10/22

~~ADO/B.W. - 7 letter no. put for signature~~

~~Do (B.W.)~~

[Signature]
17/10/22

[Signature]
ADO (B.W.)
18/10/22

MS/CC