



C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2022/ 296

Dated: 25/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Aggarwal Bikaner Sweet Corner/restaurant running at ground floor** located at **A-1/1 Bhajanpura, Near Khajoori Chowk, Delhi-110053** comprises of **Basement(closed), Ground(sweet shop/restaurant) first floor (vacant) & second floor (worker residence)**, owned/occupied by **Agarwal Bikaner Sweet Corner/restaurant**, was granted FSC by this department vide letter No. **F6/DFS/MS/EH/2019/NDZ/1830** dated **23/09/2019**. The premises was re-inspected by the officer concerned of this department on **07/10/2022** in the presence of **Mr. Sanjeev Kumar** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Assembly Building**" (**Group D**) (**Restaurant running at Ground floor only**) with effect from 25/10/2022 for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 25/10/2022 at New Delhi by.


(S.K Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Commissioner (Licensing),
1st Floor, Police Station Defence Colony, New Delhi.
Online application ID no. 2022092618201.
2. The Manager,
Agarwal Bikaner Sweet Corner/restaurant,
A-1/1 Bhajanpura, Near Khajoori Chowk, Delhi-110053.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building Aggarwal Bikaner Sweet Corner, A-1/1, Bhajanpura, Near Khajoori Chowk, Delhi-110053.
2. Type of occupancy:- Assembly Building Group-D
B + Gr + 02 Upper floor
Restaurant running on Gr. floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2019/NDZ/1830 dated 23/09/2019
5. Fire safety directives No.- NBC Part IV
6. Date of inspection:- 07/10/2022
7. Name of the inspecting officer:- Sh. A.K Jaiswal (DO/ED)
8. Name & designation of officer from the building side:- Mr. Sanjeev Kumar
9. Year of construction:- 1974 & 2000
10. Applicant's letter No:- ID no. 2022092618201 dated 29/09/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	20 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	02 No.	02 No.	MR
	B. Width of staircase			
	1. Upper floors	N/A	2 M & 1.0 M	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	02 No.	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 no. of 2 m & 1.0 m	02 no. of 2 m & 1.0 m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Heat & Smoke	N/A
	2) Location of main panel	N/A	N/A	N/A





M/8

Azadi Ka
Amrit Mahotsav

	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01 No.	01 No.	MR
	3) Hose box	01 No.	01 No.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A

A/S

	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2019/NDZ/1830 dated 23/09/2019, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

[Signature]
20/10/2022

Signature of the Inspecting Officer
Name :- A.K Jaiswal
Designation :- DO (ED)

~~Dy. CFO (NDZ)~~

Pl. spk about 1st floor.

[Signature]
12/10/22

~~DO (ED)~~

Spoken. 1st Floor is vacant
undertaking by occupier is attached
at - C-33.

Submitted pl.

~~Dy. CFO (NDZ)~~

[Signature]
18/11/2022

F.T. please.

[Signature]
18/10/22

~~DO (ED)~~

F.T. is added for sign. pl.

~~Dy. CFO (NDZ)~~
F.P. wing

[Signature]
25/10/22

[Signature]
20/10/2022