

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2022/ 297

Dated : 25/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Eating House Cafeteria (Kiosk Outside Main Gate of National Zoological Park)** located at **Main Gate of National Zoological Park, Mathura Road, New Delhi** comprised of **Ground floor only**. The FSC was earlier issued vide letter No. F6/DFS/MS/EH/NDZ/2018/1567 dated 06.07.2018. Now, the premises was re-inspected by Officers concerned of this department on dated 10.10.22 in presence of **Manager** and found that the premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises, is fit for occupancy class **Assembly Building (Group D)- Restaurant at Ground floor only** with effect from 25/10/2022 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued ..25/10/2022.....at New Delhi by.


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC Palika Kendra, New Delhi.
2. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi. **Online ID no. 20220961012519** dated **26.09.22**.
3. The Manager, Eating House Cafeteria (Kiosk Outside Main Gate of National Zoological Park), Main Gate of National Zoological Park, Mathura Road, New Delhi

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

21/14
INSPECTION REPORT

1. Name & address of the building Eating House Cafeteria (Kiosk Outside Main Gate of National Zoological Park), Main Gate of National Zoological Park, Mathura Road, New Delhi
2. Type of occupancy:- Assembly Building Group-D
Restaurant is running at Ground floor only
3. Type of case:- renewal
4. Details of previous FSC:- F6/DFS/MS/EH/NDZ/2018/1567 dated 06.07.2018
5. Fire safety directives No.- N/A
6. Date of inspection:- 10/10/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC) & Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer from the building side:- Manager
9. Year of construction:- Old Heritage 1927
10. Applicant's letter No:- Online ID no. 20220961012519 dated 26.09.22.
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12.5 mtr	12.5 mtr.	MR
	2) Gate width	3.25 mtr	3.25 mtr	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1mtr.	1mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Ground floors	12 ACPH	N/A	N/A

5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	Required
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	450 LPM	450 LPM	MR
	b) Head of main pump	40 mtr	40 mtr	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			



MR
MR
MR

	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures required under the rules, if agreed, we may renew the FSC issued vide letter no.F6/DFS/MS/EH/NDZ/2018/1567 dated 06.07.2018, Accordingly, reply letter is prepared and put up for kind perusal and approval please.

Signature of the inspecting officer

Signature of the Inspecting Officer

Rajinder Atwal
19/11/22

Ravinder Singh
19/11/22

Name: - Rajinder Atwal
Designation: - DO (CD)

Name : Ravinder Singh
Designation : ADO (CC)

Dy. Insp. (CD)
[Signature]

F.T. please.
[Signature]
20/10

ADO (CC)
[Signature]

As copy sent, this put up for kind perusal

and signature of person.

Dy. Insp. (CD)
[Signature]

F.P. wing
[Signature]
21/10/22

[Signature]
21/11/22