

C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/2022/ND2 | 480

Dated 21/10/2022

FIRE SAFETY CERTIFICATE

Certified that the Metro Star Guest House located at 2405, Faiz Road, Karol Bagh, New Delhi comprised of Ground + 03 Upper floors, Ground floor (Reception + 04 guest rooms + 01 office), 1st floor (05 guest rooms), 2nd floor (05 guest rooms) and 3rd floor (02 guest rooms) total 16 guest rooms. The FSC was earlier granted by this department vide letter No.F6/DFS/MS/GH/2016/2067 dated 28/10/19 for 16 guest rooms only. Now, the premises was re-inspected by the officers concerned of this department on 18/10/22 in the presence of Manager and found that the said guest house building having given an affidavit dated 11.10.2019 regarding not to use any floor above third floor for any purpose has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, (Sub Division-A-1) Ground floor (Reception + 04 guest rooms), 1st floor (05 guest rooms), 2nd floor (04 guest rooms) and 3rd floor (02 guest rooms) total 15 guest rooms up to third floor only, with effect from 21/10/2022 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 21/10/2022 at New Delhi by.

S.K. Dua
21/10/22
(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: kindly to ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online id no. 2022092618211 dated 10.10.2022.
3. The Manager,
Metro Star Guest House, 2405, Faiz Road, Karol Bagh, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

N/22

1. Name & address of the building Metro Star Guest House , 2405, Faiz Road, Karol Bagh, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
Gr. + 03 Upper floors (total 15 Guest rooms)
Ground floor (Reception + 04 guest rooms + 01 office), 1st floor (05 guest rooms), 2nd floor (04 guest rooms) 3rd floor (02 guest rooms) **an affidavit given by owner dated 11.10.2022 regarding not to use any floor above third floor**
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/2016/2067 dated 28/10/19.
5. Fire safety directives No.- N/A
6. Date of inspection:- 18/10/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Manager
2008
9. Year of construction:- 2008
10. Applicant's letter No:- id no. 2022092618211 dated 10.10.2022.
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr. Old Case	1.15 to 1.20 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	1. Upper floors	01	01	MR
	E. Width of corridor			
	1. Upper floors	N/A	N/A	N/A
	F. Door size			
	1. Upper floors	01 mtr	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A



	2) Upper floors	12ACPH	Natural/Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	10	10	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 M	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors Co type	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Each floor	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A


N/29

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: 01 CO₂ & 01 ABC fire extinguisher provided near electric panel.			MR


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/2016/2067 dated 28/10/19, up to third floor only under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- ADO (CC)


19/x/22
Dy. Insp. Chand


F.T. please.



20/10/22

A.D.O (CC)

Ascertainment, Arrangement for
KED Perusal and Signatures Please




F.P. Insp. 21/10/22


21/10/22