



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव


No. F6/DFS/MS/School/WZ/2022/ 1188

Dated: 21/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Prabhu Dayal Public School** located at **Primary Wing, BM Block, Shalimar Bagh, Delhi- 110088**, comprised of Basement, Ground plus two Upper Floor was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/2019/1652 dated 21.08.2019. The school building was re-inspected by the officer concerned of this department on 18.10.2022 in the presence of Ms. Manish and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC Part-IV/D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 21/10/2022 for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 21.10.2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi 110054.
2. The Offg. Principal, Prabhu Dayal Public School located at Dakshini Block-A, Shalimar Bagh, Delhi- 110088.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. All the remaining shutter type doors shall be replaced with normal wooden window before next renewal.

INSPECTION REPORT

1. Name & address of the building : Prabh Dayal Public School, Junior Wing, BM Block, Shalimar Bagh, Delhi- 110088.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/2019/1652 dated 21.08.2019
5. Fire Safety directives letter No : D.o.E Circular 262-362 dated 17.01.2005
6. Date of inspection : 18.10.2022
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO (West)
8. Name and designation of officers from the building side : Ms. Manisha
9. Year of Construction : 1989
10. Applicant's letter No. : PDPS/FS/PW/2022/684 dated 29.08.2022

The school building is comprised of basement, ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6) of DFS Act/DoE Cir. dt. 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			MR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Provided	MR
		Accessible	3.55	MR being old case
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			-----
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	03	MR
	• Basements	02	02	MR
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts	1 x 1.74 mts, 2 x 1.43 mts	MR
	• Basements	1.5, 1.25 mts	1 x 1.25 mts, 2 x 1.43 mts	MR being old case
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 mts	2.63 mts	MR
	h. Door Size	1.0 mt.	1.0 mt.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system	Not required		
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	---	----	-----
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 	----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900, 180 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 mts each	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A

	Standby power supply	N/A	N/A	N/A
Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: All the remaining shutter type doors shall be replaced with normal wooden window before next renewal.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the renewal of the NOC issued vide letter No. F.6/DFS/MS/WZ/2019/1652 dated 21.08.2019, is recommended.


DFA is put up for approval & signature please.

192/20/WZ
dt. 18/10/2022


18/10/2022

Signature of the Inspecting Officer
Divisional Officer (West Division)


~~DCFO (WZ)~~



19/10/2022

~~DCO/West~~

f.T. letter is put up for Sign. please.

~~DCFO (WZ)~~


20/10/2022


20/10/2022

WZ/ cell