

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022 / NW2 / 1187

Dated: 21 / 10 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **St. Joseph Convent School** located at **245, A-Block, Street No.03, Harit Vihar, Burari, Delhi-110084** comprised of **Ground and First Floor Only** owned/occupied by **St. Joseph Convent School** was granted FSC by this department vide letter **No.F6/DFS/MS/2017/School/WZ/1188** dated **09.08.2017**. The premises was re-inspected by the officer concerned of this department on **15.10.2022** in presence of **Sh. Keshav Kaushal (Admin)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no Director of Education letter no. 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from **21/10/2022** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **21/10/2022** at New Delhi by


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, St. Joseph Convent School located at 245, A-Block, Street No.03, Harit Vihar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate. **six months** prior to its expiry".

N/S

INSPECTION REPORT

- Name & address of the building : St. Joseph Convent School, 245, A-Block, Street No. 3, Harit Vihar, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground & First floor Only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2017/School/WZ/1188 dated: 09.08.2017
6. Fire Safety directives letter No : Nil
7. Date of inspection : 15.10.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Keshav Kaushal (Admin)
10. Year of Construction : 2014
11. Applicant's letter No. : Online E-mail dated 30.09.2022

Plot Area-2100 m2 Covered area ----600 m2 No of student—195nos. Total class room --11nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.5m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01no	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

yp

5	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06nos	07nos	MR	
		ABC/Co2	ABC--07	MR	
		Yes	Yes	MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
7	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
NA		NA	NA		
8	MOEFA	NA	NA	NA	
9	Public Address System.	NA	NA	NA	
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA	
		NA	NA	NA	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		14	Captive Water Storage for fire fighting.		
<ul style="list-style-type: none"> Underground tank capacity 			NA	NA	NA

	<ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1188 dated 09.08.2017.

DO/NW - ON Diff
~~DO efo (NZ)~~

[Signature]
 19/10/2022

[Signature]
 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

~~ADO/RN~~ N

As approved, F.T. letter is put up for your signature pl.

[Signature]
 20/10/2022
 ADO (RN)