



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/NDZ/2022/Hospital/ 482

Dated: 31 / 10 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Jag Pravesh Chandra Hospital** located at Shastri Park, East Delhi-110053, comprised of Basement, Ground & Five Upper Floors, owned / occupied by Jag Pravesh Chandra Hospital, was issued FSC vide letter No. F6/MS/DFS/Hospital/2019/NDZ/308 dated 06/02/2019. The Hospital building was re-inspected by the officers concerned of this department on 20/10/2022 in presence of Sh. Sudhir Kishor, J.E.(E) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rule, 2010 and that the building is fit for occupancy class "Institutional" (Group-C) with effect from 31 / 10 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 31/10/2022 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c
DELHI FIRE SERVICE

Copy to :-

1. The Authorized Signatory, Jag Pravesh Chandra Hospital, Shastri Park, East Delhi-110053.
2. The executive Engineer, Electrical Health Maint. Dive.(East), B-221N, GTB Hospital Complex, Shahdara, Delhi-110095.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Basement shall be used strictly as per UBBL-2016.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

N/28

1. Name & address of the building : Jag Pravesh Chandra Hospital, Shastri Park, East Delhi-110053.
2. Building is comprised : Basement, Ground plus five upper floors
3. Type of Occupancy : Institutional
4. Type of Case : Renewal
5. Details of previous NOC : F6/MS/DFS/Hospital/2019/NDZ/308 dated 06/02/2019
6. Fire Safety directives Letter No.: F6/DFS/MS/BP/Hospital/2001/95 dt 12/01/2001
7. Date of inspection : 20/10/2022
8. Name of the Inspecting Officer : Deepak Kumar, A.D.O. (Shah.) & A.K. Jaiswal, D.O. (East)
9. Name and designation of Officer from the building side : Sh. Sudhir Kishor, J.E.(E)
10. Year of Construction : 2007

11. Applicant's letter received through email Id- emd2523@gmail.com dated 18/10/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	30 m	30 m	MR
	• Gate width	4.5 m	05 m	MR
	• Width of internal road	06 m	06 m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Low rise G+1	02 Nos.	05 Nos.	MR
	• High Rise B+G+5	02 Nos.	04 Nos.	MR
	• Basement	04 Nos.	05 Nos.+1 ramp	MR
	b. Width of staircases			
	• Low rise G+1	02 m	2 No. of 2 m & 3 No. of 1.25 m	MR
	• High Rise B+G+5	02 m	01 No. of 2 m & 1 No. of 1.5 m, 2 No. of 1.25m	MR
	• Basement	1.5 m	1 no. of 1.5 m, 3 no. of 1.25 m, 1 no. of 1.10 m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	2.40 m	2.50 m	MR
	f. Door Size	2 m, 1 m	2 m, 1 m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided found functional	MR
	• Upper Floor	Required	Provided found functional	MR
5.	Fire Extinguishers			
	• Total numbers	50 nos.	110 nos.	MR
	• Types	ABC/CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

14/29

6.	First – Aid Hose Reels			
	• Total numbers on each floor	04 Nos.	Provided found functional	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Provided	MR
	• Location of Main Panel	Basement	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooters' Location	Near Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	04 No.	Provided	MR
	• Hose Box	04 No.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	08 Nos	Provided	MR
	• Hose Box	08 Nos	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2850 LPM	2850 LPM	MR
	➤ Head of main pump	60 MH	60 MH	MR
	➤ Number of main pumps	03 No.	03 No.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	60 MH	60 MH	MR
	➤ Standby Pump out put	2850 LPM	2850 LPM	MR
	➤ Standby Pump Head	60 MH	60 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
4.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltr	2,00,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltr	Provided	MR

[Handwritten signature]

N/30

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR ✓
	➤ Flow Switch Panel	Required	Provided	MR ✓
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note :- Shortcomings issued by this department vide letter No. F6/DFS/MS/Hosp./2022/NDZ/1364 dated 10/06/2022 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/MS/DFS/Hospital/2019/NDZ/308 dated 06/02/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Deepak
21/10/2022

Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : A.D.O. (Shah.)

Ashok
21/11/2022

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

~~DCFO (NDZ)~~ *King*
25/11/22

~~C.F.O.~~ *Umesh*
25/11/2022

~~Director~~ *Umesh*
25/11/22

~~DLF/NA~~

~~ADD (Shah.)~~

Put up F.T. pl.

King
26/10

P.T.O.