



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/Cinema/NDZ/2022/ WS6

Dated: 01/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Cinapolis Cinema (Total no. 03 Auditorium, Audi- I, Audi- II & Audi-III)** located at **first & second floor, Plot no. 10, V3S Mall District Centre, Laxmi Nagar, Delhi**, owned/occupied by M/s Cinapolis India Privated Limited, was granted FSC by this department vide letter **No.F6/DFS/MS/Cinema/2020/NDZ/24** dated **13/01/2020**. The premises was re-inspected by the officers concerned of this department on **17/10/2022** in the presence of Mr. Tarun Awal (Manager) and found that the said premises have deemed complied with the NBC Part-IV and that the premises fit for occupancy class "**Assembly Building**" (**Group D**) with effect from 01/11/2022 for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 01/11/22 at New Delhi by.


(S.K Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Commissioner (Licensing),
1st Floor, Police Station Defence Colony, New Delhi.
2. The Manager,
Cinapolis Cinema,
First & Second floor, Plot no. 10, V3S Mall District Centre,
Laxmi Nagar, Delhi-92.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building | Cinepolis Cinema at V3S East Centre Mall
at Plot no. 10, V3S Mall District Centre,
Laxmi Nagar, Delhi. |
| 2. Type of occupancy:- | Mercantile (Mixed Occupancy)
B + Gr + 03 Upper floors
Cinema Hall on 1 st & 2 nd floor |
| 3. Type of case:- | Renewal |
| 4. Details of previous FSC:- | No.F6/DFS/MS/Cinema/2020/NDZ/24
dated 13/01/2020 |
| 5. Fire safety directives No.- | F6/MS/DFS/BP/2004/863 dated 16/04/04 |
| 6. Date of inspection:- | 17/10/2022 |
| 7. Name of the inspecting officer:- | Sh. A.K. Jaiswal (DO/ED) &
Sh. Manoj Kumar Sharma (DO) |
| 8. Name & designation of officer
from the building side:- | Mr. Tarun Awal (Manager) |
| 9. Year of construction:- | 2006 |
| 10. Applicant's letter No:- | email dated 29/09/2022 |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 M	36 M & 13.8 M	MR
	2) Gate width	4.5 M	06 M	MR
	3) Width of internal road	06 M	06 M	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	06 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 M	1.5 M & 1.8 M	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 M	1.5 M	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	02 hrs	02 hrs	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR

(Handwritten signature)



5.	Fire Extinguishers			
	1) Total numbers	21 Nos.	24 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 no.	02 no.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Heat & Smoke	Heat & Smoke	MR
	2) Location of main panel	Control room	Basement	MR
	3) Location of repeater panel	Security room	Provided	MR
	4) Alternate source of power	Battery & DG set	Provided	MR
	5) Hooter's Location	Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System (Common with Mall)			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants (Common with Mall)			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	02 No.	02 No.	MR
	3) Hose box	02 No.	02 No.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	05 No.	05 No.	MR
	2) Hose box	05 No.	05 No.	MR
13.	Pumping Arrangement	Common with Mall		
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	01 nos.	01 nos.	MR
	d) Jockey pump out put	180 Lpm	180 Lpm	MR
	e) Jockey pump head	70 M	70 M	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Required	Auto	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting (Common with Mall)			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR

29

29

	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	40,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	Provided in all LT & HT Panels	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/Cinema/2020/NDZ/24 dated 13/01/2020, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

A.K. Jaiswal
20/11/2022

M.K. Sharma

Name :- A.K. Jaiswal
Designation :- DO (ED)

Name :- M.K. Sharma
Designation :- DO(LN)

By: CFQ (NDZ) F.T. please.

25/10

DO (MKS) F.T. letter is put up for sig. pl

DO (NDZ)

29/10/22

F.P. Winy

M.K. Sharma
29/10