

C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/ DFS/MS/School/2022/ NW2/1195

Dated: 27/10/2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Sarvodaya Kanya Vidyalaya No-1** located at **Model Town-III, Delhi-110009** comprised of **02 blocks Ground & First Floor Each** owned/occupied by **Govt. Sarvodaya Kanya Vidyalaya No-1** was granted FSC by this department vide letter no. **F6/DFS/MS/School/2019/2157** dated **15.11.2019** the premises was re-inspected by the officer concerned of this department on **12.10.2022** in presence of **Sh. Ram Kishan (Lecturer)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from 27/10/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 27/10/2022 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya No-1 located at Model Town-III, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate. **six months** prior to its expiry".

INSPECTION REPORT

	Name & address of the building	: Govt. Sarvodaya Kanya Vidyalaya No-1, Model Town-III, Delhi-09.
N/A 2	Type of Occupancy	: Educational
3	Composition of building	: 02 blocks (Ground & First Floor Each)
4	Type of Case	: Renewal
5	Details of previous NOC	: F6/DFS/MS/School/2019/2157 Dated 15.11.2019
6	Fire Safety directives letter No	: Director of Education Circular dated 01.03.2011
7	Date of inspection	: 12.10.2022
8	Name of the Inspecting Officers	: ADO (RN)
9	Name and designation of officers from the building side	: Sh. Ram Kishan (Lecturer)
10	Year of Construction	: 1952
11	Applicant's letter No.	: SKV/MT/ NO.1/360 Dated:01.10.2022

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Requirements 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.5m	1.6m, 2m, 1.43m & 1.10m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	2.10m	NA	
f. Door Size	1 m	1.07m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	14nos	15nos	MR

Jp

	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	NA	N/A	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.2157 dated 15.11.2019.

DO/NW - ON Leave

~~DO (SW)~~ 13/10/22

~~DO (NW)~~ 17/10/22

~~ADO/RN~~

As approved, F.T. Letter is put up for your signature pl.

Signature of the Inspecting Officer
 Name - C.L. Meena
 Designation:- ADO/RN

19/10/2022 cont