



C/59

459

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/NDZ/2022/

1202

Dated:- 03/11/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Mayur Public School** located at **I.P. extension, Delhi-92** comprised of **Ground + 03 Upper floors** owned/occupied by Mayur Public School, was granted FSC by this department vide letter No. **F6/DFS/MS/School/2018/NDZ/236 dated 09/02/2018**. The premises was re-inspected by the officer concerned of this department on 29/09/2022 in the presence of the Mrs. Shankuntla Rawat (Principal) and found that school building having been given an undertaking dated 29.09.2022 requesting not to use temporary structure (on terrace) and a small basement separated from main building has deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that school premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. (B-I) Gr. + 03 upper floors only**, with effect from **03-11-2022** for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on **03/11/2022** at New Delhi by.

*S.K. Dua*  
02/11/22

Dy. Chief Fire Officer  
Delhi Fire Service

*Me*

Copy to:-

1. The Director of Education,  
Govt. of NCT Delhi, Old Sectt. Delhi - 110054.
2. The Principal,  
Mayur Public School,  
I.P. extension, Delhi-92.
3. The Commissioner,  
MCD, Dr. S.P Mukherjee Civic Centre, JLN Marg,  
New Delhi-110002.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. MCD to take necessary action as deemed fit.



**INSPECTION REPORT**

1. Name & address of the building: Mayur Public School located at I.P. extension, Delhi-92
2. Type of occupancy:- Educational Group-B  
Ground + 03 Upper floors + Basement & Temporary terrace floor (Sealed)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2018/NDZ/236 dated 09/02/2018
5. Fire safety directives No.- N/A
6. Date of inspection:- 29/09/2022
7. Name of the inspecting officer:- Sh. A.K. Jaiswal (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer From the building side:- Mrs. Shankuntla Rawat (Principal)
9. Year of construction:- 2000
10. Applicant's letter No:- email dated 20/09/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	10 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	04 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m	1.7 mtr. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	12 Nos.	MR



	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	23 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	100 mm	N/A
	2) Number of hydrants per floor	N/A	2 no.	N/A
	3) Hose box	N/A	2 no.	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

*[Handwritten signature]*

*[Handwritten mark]*

MR  
MR  
MR  
MR  
MR

		10,000 ltrs. Required	10,000 ltrs. Provided	MR MR
15.	d) Over head tank capacity			
	Exit Signage.			
16.	Provision of Lifts.			N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	MR
17.	Stand by Power Supply	Required	Provided	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.  
 Shortcomings communicated vide letter No. F6/DFS/MS/School/2021/100 dated 24/02/2021 have been rectified. (Undertaking and photos enclosed at C/54 & 55).  
 In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/NDZ/236 dated 09/02/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

*Mersh*

Signature of the Inspection Officer  
 Name :- M.K. Sharma  
 Designation:- ADO/LN

*A.K. Jaiswal*  
 26/11/2022

Signature of the Inspection Officer  
 Name :- A.K. Jaiswal  
 Designation:- DO/ED

*By. CFO (NDZ)*

*Put up corrected F.T. letter as per n/s.*

*DO (MKS)*

*corrected F.T. & letter put up*

*DEFO (NDZ)*

*F.P. wing*

*28/11*

*Mersh*  
 01/12