



451

7-11-2022

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2022/1201

Dated:- 03/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Bharti Public School** located at **Sawasthya Vihar, Vikas Marg, Delhi-92** comprised of **Ground + 03 Upper floors + Temporary shed at terrace (Scaled)**, owned/occupied by M/s Bharti Public School, was granted FSC by this department vide letter No. **F6/DFS/MS/School/2017/NDZ/1707 dated 27/11/2017**. The premises was re-inspected by the officer concerned of this department on 20/09/2022 in the presence of the Ms. S. Arora (Principal) and found that school building having been given an undertaking dated 20.09.2022 requesting not to use temporary structure (on terrace) has deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that school premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. (B-I) Gr. + 3 upper floors only**, with effect from 03/11/2022 2022 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ... 03/11/2022 at New Delhi by.



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Director of Education,
Govt. of NCT Delhi, Old Sectt. Delhi - 110054.
2. The Principal ,
M/s Bharti Public School,
Sawasthya Vihar, Vikas Marg, Delhi-92.
- 3 The Commissioner,
MCD, Dr. S.P Mukherjee Civic Centre, JLN Marg,
New Delhi-110002.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. MCD to take necessary action as deemed fit.

INSPECTION REPORT

1. Name & address of the building Bharti Public School
Sawasthya Vihar, Vikas Marg, Delhi-92
2. Type of occupancy:- Educational Group-B
Ground + 03 Upper floors + Temporary
shed at terrace (Sealed)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/2017/NDZ/1707 dated
27/11/2017
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/09/2022
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. S. Arora (Principal)
9. Year of construction:- 1996
10. Applicant's letter No:- BPS/SV/2022/9117 dated 22/07/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	30 ft.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	04 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m	1.5, 1.46, 1.47 & 1.5 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 nos.	04 nos.	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	17 Nos.	18 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR



-N/21-



6.	First-Aid Hose Reel			
	1) Total number of each floor	03 nos.	03 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	2 no.	2 no.	MR
	3) Hose box	2 no.	2 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	01	N/A
	2) Hose box	N/A	01	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5,000 ltrs.	5,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

Mo

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/School/2021/176 dated 01/04/2021 have been rectified. (Undertaking and photos enclosed at C/45)

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/1707 dated 27/11/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
24/11

Name :- M.K. Sharma
Designation :- ADO (LN)

~~DO/ED~~

Submitted for approval pl.

~~Dr. CFO (NDZ)~~

Approval
26/10/2022
Put up F.T. letter as approved for Mayur Public School, I.P. Extn.

~~DO (MKS)~~

Copy as approved in Mayur Public School is put up for copy pl.

~~Dr. CFO (NDZ)~~

Dr. CFO
02/11
F.P. wing

M.K. Sharma
24/11