

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/ 490

Dated: 03/11/2022

FIRE SAFETY CERTIFICATE

Certified that the building of The Apna Villa CGHS Ltd. Located at Plot No – 23, Sector – 10, Dwarka, New Delhi – 110075 having 4 blocks, comprised of stilt + six / eight upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CGHS/2017/SZ/1411 dated 25/09/2017. The premise was re inspected by the officer concerned of this department on 07/10/2022 in the presence of. Sh. Vijay Kumar (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Residential Building” Group A-4 with effect from 03/11/2022 for a period of **five years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/11/2022 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The President, The Apna Villa CGHS Ltd. Located at Plot No – 23, Sector – 10, Dwarka, New Delhi – 110075.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: The Apna Villa CGHS Ltd. Located at Plot No – 23, Sector – 10, Dwarka, New Delhi – 110075
2. Type of Occupancy : Residential Building “A” (Apartment)
3. Type of Case : Renewal (4 blocks, stilt + 06 / 08 UFs)
4. Details of previous NO:F6/DFS/MS/CGHS/2017/SZ/1411 dated 25/09/2017
5. Fire Safety directives L. No. : F6/DFS/MS/96/CGHS/1297 dated 11/10/1996
& F6/DFS/MS/CGHS/BP/09/659 dated 05/03/2009
6. Date of inspection : 07/10/2022
7. Name of the Inspecting Officer : Sh. Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Vijay Kumar (Manager)
9. Year of Construction : 1995-96
10. Applicant's letter No. : Nildated-19/09/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per- N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	Provided	MR
	• Gate width	4.5 mtrs	Provided	MR
	• Width of internal road	6 mtrs	Old case	MR (Being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 no. each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	Old case	1.16 mtr each	MR (Being old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	04	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr	Provided	MR (Being old case)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR



5.	Fire Extinguishers			
	• Total numbers	2 at each floor	Provided	MR
	• Types	CO ₂ & ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 each block	01 each block	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	04 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	450 LPM	450 LPM	MR
	• Terrace level	40 mtrs	40 mtrs	MR
	➤ Discharge of pump	Required	Provided	MR
	➤ Head of the pump	Required	Nonfunctional	NMR
	➤ Power supply			
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr each block	Provided	MR
15	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	NA	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/CGHS/2017/SZ/1411 dated 25/09/2017 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name *Uday Vir Singh*
Designation *AO/MS*

NO/20 *Uday Vir Singh*

Dy. Secy (S2)

CFO *14/10/2017*

Director *14/10/2017*

Director *14/10/2017*

F. f. is put up for signature please.