



C/72

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/EH/309

Dated: 04/11/2022

FIRE SAFETY CERTIFICATE

Certified that the building Fam Jam Restaurant (A Unit of Vashisth Enterprises)" located at Plot No. 03, First floor, MLU Manish Twin Plaza – 2, Sector – 11, Dwarka, New – Delhi 110078 is running at 1st floor in a building comprised of G + 03 UF was issued Fire Safety Certificate vide letter No. F6/DFS/MS/EH/2019/SZ/2178 dated 19/11/2019 (Issued to M/s Password Restaurant earlier running in the same premises). The premises was re inspected by the officer concerned of this department on 23/09/2022 in the presence of Mr. Shubham Vasisht and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D (1st Floor Only) with effect from 04/11/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/11/2022 at New Delhi by.

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Add. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Manager Fam Jam Restaurant (A Unit of Vashisth Enterprises)" located at Plot No. 03, First floor, MLU Manish Twin Plaza – 2, Sector – 11, Dwarka, New – Delhi 110078.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Fam Jam Restaurant (A Unit of Vashisth Enterprises)" located at Plot No. 03, First floor, MLU Manish Twin Plaza – 2, Sector – 11, Dwarka, New – Delhi 110078.

2. Type of Occupancy : Assembly D (Restaurant)

3. Type of Case : Renewal ((**Restaurant is running at 1st Floor** in a building comprised of G+3UF.

4. Details of previous NOC: F6/DFS/MS/EH/2019/SZ/2178 dated 19/11/19
(Issued to M/s Password Restaurant)

5. Fire Safety directives Letter No. : Old Case / Circular dated 11/11/2005

6. Date of inspection : 23/09/2022

7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)

8. Name and designation of Officer
from the building side : Mr. Shubham Vasisht

9. Year of Construction : Before 2009

10. Applicant's letter No. : 2022091017330 dated 12/09/2022

Sr. No	Minimum standards on fire prevention and fire safety U/R 33	As per N/15, N/16 & N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtr	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 no.	01 no.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25 m	Old case	MR(Being old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.20 m & 1 m	Old case	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/24

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Exhaust Fans	MR
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	Provided	MR
	• Types	ABC or CO2	ABC	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1 No	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided in restaurant	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm, 180 lpm	Provided	MR
	➤ Head of the pump	35 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

~125

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 liters	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC Fire Extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2019/SZ/2178 Dated 19/11/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name
 Designation

[Handwritten Signature]
 26/9/22
 Name: *[Handwritten Name]*
 Designation: *[Handwritten Designation]*

[Handwritten Signatures and Dates]
 27/9/22
 ADO (S2)
 ADO (W/K)