

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/1223

Dated: 09/11/2022

FIRE SAFETY CERTIFICATE

Certified that MC Primary School, located at B- Block, C. R Park, New Delhi 110019 comprised of Ground plus one upper floor owned/ occupied by Municipal Corporation of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/1791 Dated 18-09-2019. The said premise was re-inspected by officer concerned of this department on 01/11/2022 in presence of Smt. Anju Mittal (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 09/11/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 09/11,2022 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The Principal, MC Primary School, B- Block, C. R Park, New Delhi 110019.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	MC Primary School, B- Block, C. R Park, New Delhi 110019		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus one upper floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/1791 Dated 18-09-2019		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	01/11/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Smt. Anju Mittal (Principal)		
10	Year of construction	2009		
11	Applicant letter No.	Email of dated 30/09/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible NA -NA-	06 mtr 4.50 mtr -NA-	MR NA -NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50m /0.75m	1.43m & 1.30m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	1 No	Provided	MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	30 ACPH 12 ACPH	-NA- NA	-NA- NA
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Required ABC / CO2 ISI marked	06 Nos ABC & CO2 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	-NA-	-NA-	-NA-


N/13

	• PA system panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection


Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/DFS/MS/School/2019/SZ/1791 Dated 18-09-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name Sh Rajesh Kumar
 Design. ADO (BCP)


Dy. CFO (SZ)

F.T.

ADO (BCP) 

As approved, F.T. letter is put up for your signature pl

104
02/11/2022

Dy CFO/SZ 

M.S. Ull