

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS /SZ/2022/ 507

Dated: 14/11/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building (S-2 Block (SSLS, SMS & SIT Building) (Commonly known as C,D & E Blocks) GGSIP University Located at Sector 16C, Dwarka, New Delhi comprised of G+ 06 UF was issued Fire Safety Certificate vide Letter No: F6/DFS/MS/2011/2320, dated 26/09/2011. The premises was re inspected by the team of officers concerned of this department on 20/10/2022 in the presence of Sh. Deepesh Singh Bhati A.E(E) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" Group B with effect from 14/11/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/11/2022 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Registrar (E&S), GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
2. The Astt. Registrar to the Hon'ble Vice Chancellor, GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
3. The Executive Engineer (UWD, GGSIPU) University Works Division, Ground Floor, Library Block, Guru Gobind Singh Indraprastha University, Sector 16-C, Dwarka New Delhi-110078.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its

N/69

**INSPECTION REPORT**

1. Name & address of the building: GGSIP University Located at Sector 16C, Dwarka, New Delhi.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (S-2 Block (SSLS, SMS & SIT Building)( Commonly known as C,D & E Blocks Ground + 06 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/2011/2320, dated 26/09/2011
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2006/1208, dated 25/05/2006
6. Date of inspection : 20/10/2022
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Deepesh Singh Bhati J.E(E)
9. Year of Construction : 2006
10. Applicant's letter No. : Email Dated-08/10/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement As per N/62, N/63 & N/64	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	05 mtrs	Provided	MR
	• Width of internal road	06 mtr	Old case	MR being old case
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 No's each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5mtr each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	03 No's each block	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1.5 mtr	Provided (Old case)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	02 Hrs rating	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required in seminar hall	Provided	MR

5.	Fire Extinguishers			
	• Total numbers	06 nos each floor	45 Nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	02 nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	02 Nos.	Provided	MR
	• Hose Box	02 Nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	12 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:	<i>Pumping Arrangement is Common for entire University</i>		
	• Ground Level	2280 Lpm	Provided	MR
	• Discharge of main pump	70 mtr	Provided	MR
	• Head of main pump	01	Provided	MR
	• Number of main pumps	180 LPM	Provided	MR
	• Jockey pump out put	70 mtr	Provided	MR
	• Jockey pump head	2850 LPM	Provided	MR
	• Standby Pump out put	70 mtr	Provided	MR
	• Standby Pump Head	Required	Provided	MR
	• Auto Staring/Manual stopping	Required	Provided	MR
	• Pump House Access	Required	Provided	MR
	• Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:	<i>Common for entire University</i>		
	• Under ground tank capacity	2,00,000 ltr	Provided	MR
	• Draw off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000Ltr each block	Provided	MR
15	Exit Signage	Required	Provided	MR

*Jw*      *h*

N/71

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2011/2320, dated 26/09/2011 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Handwritten Signature]*  
27/10/22

Signature of the Inspecting Officer  
Name: Sh. Vedpal  
Designation: DO/SW

*[Handwritten Signature]*  
27/10/22

Signature of the Inspecting Officer  
Name: Udai Vir Singh  
Designation: ADO/DWK

*[Handwritten Signature]*  
27/11/22

*[Handwritten Signature]*  
27/11/22

*[Handwritten Signature]*  
27/11/22

*[Handwritten Signature]*  
27/11/22

*[Handwritten Signature]*  
27/11/22