



C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2022/NDZ/School/1232

Dated: 15/11/2022

FIRE SAFETY CERTIFICATE

Certified that the Adarsh Gyan Sarover Balika Vidyalaya located at Marginal Bandh, Main Road (5th Pusta), Ganwari, Delhi-110053, building comprised of Ground plus Two upper Floors only owned / occupied by Adarsh Gyan Sarover Balika Vidyalaya, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/1766 Dated 12/09/19. The School building was re-inspected by the officer concerned of this department on 28/10/2022 in presence of Sh. Rajiv (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from ___ / ___ /2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 15/11/2022 at New Delhi by.


(S.K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE.**



Copy to :-

1. The Principal, Adarsh Gyan Sarover Balika Vidyalaya, Marginal Bandh, Main Road (5th Pusta), Ganwari, Delhi-110053.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

N/116



SINSPECTION REPORT

1. Name & address of the building : Adarsh Gyan Sarover Balika Vidyalaya at Marginal Bandh, Main Road (5th Pusta), Ganwari, Delhi-110053.
2. Building is comprised of : Ground & Two Upper Floors only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/1766 Dated 12/09/19
6. Fire Safety directives Letter No.: NBC (Part-IV)
7. Date of inspection : 28/10/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer from the building side : Sh. Rajiv (Manager)
10. Year of Construction : 1994

11. Applicant's letter received through email dated : 19/10/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at Site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	15 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR ✓
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5 m	2 x 1.50m & 1 x 1.10m	MR ✓
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	1.50 mtrs	1.50 mtrs	MR ✓
	f. Door Size	1.00 mtr	1.00 mtr	MR ✓
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 nos.	10 nos.	MR ✓
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

11/17

6.	First Aid Hose Reels			
	• Total numbers on each floor	01 Nos	01 Nos	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000	N/A	N/A
15.	Exit Signage.	Required	Provided	MR

[Handwritten signature]

N/18

16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/1766 Dated 12/09/19 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ak Jaiswal
7/11/2022

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

~~Dy. CFO (NDS)~~

F.T. please.

King
11/11/22

~~DO (ED)~~

F.T. is added to-

~~Dy. CFO (NDS)~~

Ak Jaiswal
14/11/2022

King
15/11

F.P. wing