



420



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/WZ/School/2022/1240


Dated 15/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Shaheed Bishan Singh Memorial Sr. Sec. School**, located at **F-213, A, Mansarovar Garden, New Delhi – 110015**, comprised of Ground + 02 upper floors only Owned/occupied by **Shaheed Bishan Singh Memorial Sr. Sec. School** was issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2019/2177 Dated 19/11/2019. The premises was re-inspected by officer concern of this department on 07/11/2022 in the presence of Smt. Puja Singhal (Principal) and observed that fire prevention and fire safety arrangements provide in the premises found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with DOE circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the building/premises is fit for occupancy class “Educational Building” (Group-B) with effect from 15/11/2022 for a period of Three years, accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 & subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to the compliance of the conditions printed overleaf.

Issued on 15/11/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone


14/11/2022

Copy to: -

1. The Principal, Shaheed Bishan Singh Memorial Sr. Sec. School, located at F-213, A, Mansarovar Garden, New Delhi – 110015.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **This NOC/FFSC is valid for Ground + 02 Upper Floors only.**

INSPECTION REPORT

1. Name & address of the building : **Shaheed Bishan Singh Memorial Sr. Sec. School**, located at **F-213, A, Mansarovar Garden, New Delhi – 110015.**
2. Type of Occupancy : Educational (G + 02 Upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/WZ/2019/2177 Dated 19/11/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 07/11/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Smt. Puja Singhal (Principal)
9. Year of Construction : 1990(As per prev. insp. rept. Dated. – 07/11/2019)
10. Applicant's letter No. : Email dated 13/10/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular. No 3298 – 3398 dated 01/03/2011/As per prev. insp. rept. Dated. – 07/11/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02 Provided	MR(Old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old case	1X1.35 mtr, 1X 1.05 mtr	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5mts	Provided	MR
	g. Door Size	1 mtrs	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR



6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01 each floor	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mtr	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NR	NR	NR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 mtr	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F.6/DFS/MS/School/WZ/2019/2177 dated 19/11/2019 renewal under DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.

~~Do (west)~~

~~Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN)~~

365/AD0/mn
07/11/2022

~~dy~~
08/11/2022

~~DFS (wz)~~

~~Signature~~

~~ADOMN~~

Mr. F. T is put up for your kind personal & signature please.

~~Signature~~
14/11/2022

~~Signature~~

~~Signature~~
15/11/2022

MS/ cell

D.O. (WEST) 735
DATED. 8/11/2022