

C 29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6 DFS/MS/School/SZ/2022/1268

Dated: 25/11/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Baba Ram Dev Sarvodaya Kanya Vidyalaya, Prasad Nagar, New Delhi- 110005**, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2019/2108 dated 04.11.2019, for two blocks namely Main Block & Primary Block. Main Block is comprised of ground plus three upper floors & Primary Block is comprised of ground floor only. The school building was re-inspected by the officer concerned of this department on 14.11.2022 in the presence of Smt. Mamta Vaid (Vice Principal) and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010, and that the building/premises is fit for occupancy class **"Educational"** with effect from 25/11/2022 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 25/11/2022 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The HOS, BRD Sarvodaya Kanya Vidyalaya, Prasad Nagar, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

**INSPECTION REPORT**

1. Name & address of the building : Baba Ram Dev Sarvodaya Kanya Vidyalaya, Prasad Nagar, New Delhi- 05.
2. Type of Occupancy : Educational
3. Building Composition : The said school building complex is comprised of two blocks- main block is comprised of ground plus three upper floors and primary block is comprised of ground floor only.
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2019/2108 dated 04.11.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 14.11.2022
8. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
9. Name and designation of officers from the building side : Smt. Mamta Vaid, Vice Principal
9. Year of Construction : 1980
10. Applicant's letter No. : letter No. BRD/SKV/PN/147 dated 03.11.2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire Safety Requirements as per FSC dt. 04.11.2019	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	05 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 in main block	Provided (02 Nos.)	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt.	1.5 mts. each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	3.70, 2.35 mts	MR
	h. Door Size	Old Case	1.04 mts	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			



Exit Signage.

Provision of Lifts.

- Pressurization of Lift Shaft
- Pressurization of Lift lobby
- Communication In lift Car
- Fireman's Grounding Switch
- Lift Signage

Required	Provided	MR
<b>Not Applicable</b>		
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	Provided	N/A

17 Standby power supply

18 Refuge Area.

- Total Area
- Location

N/A	N/A	N/A
N/A	N/A	N/A

19 Fire Control Room

- Detector System Panel
- Flow Switch Panel
- PA System Panel
- Batter backup
- Building Floor Plans

N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A
N/A	N/A	N/A

20 Special Fire Protection Systems for Protection of special Risks, if any

N/A	N/A	N/A
-----	-----	-----

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection

In view of deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the NOC issued vide letter No.F.6/DFS/MS/School/SZ/2019/2108 dated 04.11.2019, renewal under Rule 37 of Delhi Fire Service Rules- 2010.

DFA is put up for approval & signature please

*[Handwritten signature]* 15/11/22

Signature of the Inspecting Officer  
(P.V. Rathee)  
Asstt. Div. Officer. (SRD)

*D.O (SU)*  
*Dy CRO (SU)*  
*ADD FAN*  
 F.T. Letter is per est for sign please  
*DY CRO (SU)*  
*M.S. Cell*