

C 72

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2022/NDZ/334

Dated : 28/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Bikanerwala Foods Pvt. Ltd. located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi**, in a building comprised of 2 Basements, Ground + 03 Upper floors **but restaurant running at first floor (only)**, was earlier granted FSC vide letter No. **F6/DFS/MS/EH/2017/1446** dated **04/10/17**. Now, the premises was re-inspected by the officers concerned of this department on 16/11/22 in the presence of **Sh. Vishnu** and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for **Assembly Occupancy - for Restaurant running at First floor only** with effect from **28/11/2022** for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued.....**28/11/2022**.....at New Delhi by.


(S.K.Dua)

Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. The Medical Health Officer, NDMC , Palika Kendra , New Delhi :
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
ID no-2020091607007 dated 16/09/2020 & mail id timeoffice@bikano.com>dated 11.11.2022.
3. The Manager, Bikanerwala Foods Pvt. Ltd, Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is only for restaurant at first floor only. .
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned .
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

2/19
INSPECTION REPORT

1. Name & address of the building M/s Bikanerwala Foods Pvt. Ltd. located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi.
2. Type of occupancy:- Assembly Building Group-D
2 B + Gr. + 03 upper floor
Restaurant running at 1st floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2017/1446 dated 04/10/17
5. Fire safety directives No.- N/A
6. Date of inspection:- 16/11/2022
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Mr. Vishnu old
9. Year of construction:-
10. Applicant's letter No:- online application ID-2020091607007 dated 16/09/2020 & mail id timeoffice@bikano.com dated 11.11.2022.

				Renewal
S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	9 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr.	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

N/20

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors (smoke)	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	02	MR
	3) Hose box	01	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	02	N/A
	2) Hose box	N/A	02	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	
	f) Stand by pump output	2280 LPM	2280 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A



1121

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2017/1446 dated 04/10/17. Accordingly, reply letter is prepared and put up for kind perusal and approval please.

Signature of the Inspecting Officer

[Handwritten Signature]
18/11/22

Name :- Ravinder Singh
Designation :- ADO (CC)

[Handwritten]
Dy/CO
21/11/22

[Handwritten]
Dy. CO (CC-2)
ADDO (CC)

[Handwritten]
f.T. please.
22/11/22

[Handwritten]
As proposed Prishtunus forwarded
renewed and signature please
24/11/22

[Handwritten]
Dy. CO (CC-2)
F.P. wing
25/11/22