



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No: F.6/DFS/MS/Cinema/WZ/2022/ 518

Dated: 21/11/2022

FIRE SAFETY CERTIFICATE

Certified that M/s. Cinopolis India Pvt. Ltd. Multiplex/Cinema (09 Audis/Screen Cinema) running at 3rd & 4th Floor of Pacific Mall building comprised of 02 basements, lower ground, ground plus four upper floors, owned/occupied by M/s. Cinopolis India Pvt. Ltd., was inspected by the officers concerned of this department on 15.11.2022 in presence of Mr. Manish Karanwal (Regional Manager) and found that the Cinopolis Multiplex/Cinema, Pacific Mall, Netaji Subhash Place, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for Occupancy Class- D (Assembly- Cinema) with effect from the date of issue of this certificate for a period of 03 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules- 2010, printed overleaf.

Issued on 21/11/2022 at New Delhi by.


(Atul Garg)
Director
9-11/11

Copy to: -

1. The Manager, Cinopolis Cinema, 3rd & 4th Floor, Pacific Mall, Netaji Subhash Place Metro Station, New Delhi- 110034.
2. Sh. Shahzad Alam, Sub Divisional Magistrate (Rohini), Office of the Dy. Commissioner, District North-West, Kanjhawla, Delhi- 110081.

Conditions for the validity of fire safety certificate

1. Providing of fire safety measures does not give any guarantee that there will be No fire. These equipments/installation can minimize the losses if maintained in good working condition and handled efficiently in case of fire.
2. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Cinepolis India Pvt. Ltd, Pacific Mall, NSP, New Delhi
1. Type of Occupancy : Assembly
2. Type of Case : New Case
3. Details of previous NOC : N/A
4. Fire Safety directives letter No : F6/DFS/MS/BP/2019/149 dated 16.04.2019
5. Date of inspection : 15.11.2022
6. Name of the Inspecting Officers : Dharampal Bhardwaj, DCFO, M.K.Chattopadhyay, D.O (West)
7. Name and designation of officers from the building side : Sh. Manish Karanwal (Regional Manager)
9. Year of Construction : 2019
10. Applicant's letter No. : E-mail eocnorthwest@gmail.com dated 11.11.2022

Cinepolis Audi's are located at third & fourth floor of Pacific Mall building comprised of 02 basements, lower ground, ground and four upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width 	12 mts	Provided	MR
	<ul style="list-style-type: none"> Gate width 	06 mts	Directly accessible from the road	MR
	<ul style="list-style-type: none"> Width of internal road 	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> Upper Floors 	Total-08 Nos.	Provided	MR
	<ul style="list-style-type: none"> Basements 	02 nos.	Provided by mall	N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> Upper Floors 	02 mts each	Provided	MR
	<ul style="list-style-type: none"> Basements 	1.5 each	Provided by mall	MR
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	MR
	e. No. of continuous staircases to terrace	03 Nos.	Provided	MR
	g. Width of Corridor	02 mts	Provided	MR
	h. Door Size	2.0 mts	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Provided	MR

[Signature]

5	Fire Extinguishers			
	• Total numbers	25 nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02 Nos. at each Audi	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Beam detector	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Appropriate place	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per Audi	02 Nos	Provided	MR
	• Hose Box per Audi	02 Nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided by mall	MR
	• Hose Box	Required	Provided by mall	MR
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	2280 LPM	Provided by mall	MR
	➤ Head of Main pump	88 mts.	Provided by mall	MR
	➤ Number of main pumps	02 Nos.	Provided by mall	MR
	➤ Jockey Pump out put	2 x 180 LPM	Provided by mall	MR
	➤ Jockey pump head	88 mts.	Provided by mall	MR
	➤ Standby Pump out put	2280 LPM	Provided by mall	MR
	➤ Standby Pump Head	88 mts.	Provided by mall	MR
	➤ Auto Starting/ Manual stopping	Required	Provided by mall	MR
	➤ Pump House Access	Required	Provided by mall	MR
	• Terrace level	----	-----	-----
	➤ Discharge of pump	900 LPM	Provided by mall	MR
	➤ Head of the pump	40 mts	Provided by mall	MR
	➤ Power Supply	Required	Provided by mall	MR
	➤ Auto Starting of pump	Required	Provided by mall	MR

Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	2,00, 000 lts.	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		20,000 lts	Provided by mall	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
17	Standby power supply	Required	Provided by mall	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room Provided by Mall			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
		Required	Provided by mall	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	ABC type fire extinguishers found provided near LT Panels.	MR

The fire protection systems provided in the building were randomly test checked and found functional at the time of inspection.

Note:- All the shortcomings pointed out by this department vide letter No. F6/DFS/MS/Cinema/WZ/2022/2489 dated 30.09.2022 have been complied with by the cinema management.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act- 2007 & Rules- 2010.

DFA is put up for approval & signature please

Signature of the Inspecting Officer
DHARAMPAL BHARDWAJ
Dy. Chief Fire Officer (West Zone)

Signature of the Inspecting Officer
M.K. CHATTOPADHYAY
Divisional Officer (West)

CFO 18/11/22
Director 18/11/22

DC/18/11/22

DO WEST/43
DATE 17/11/2022