



424



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No.F.6/DFS/MS/School/2022/NDZ/ 1258

Dated: 24 / 11 /2022

**FIRE SAFETY CERTIFICATE**

Certified that City Convent Sec. School at C-19, New Modern Shahdara, Delhi-110032, comprised of Ground plus Two upper floors, owned / occupied by City Convent Sec. School, was issued FSC vide letter No. F6/DFS/MS/School/2018/NDZ/2099 Dated 13/09/2018. The premises was re-inspected by the team of officers concerned of this department on dated 09/11/2022 in the presence of Mr. Aman Chaudhary, Administrator of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and the building/premises is fit for occupancy class "Educational" (Group-B) with effect from 24 / 11 /2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

**Issued on** 24/11/2022 **at New Delhi by.**

  
(S.K. DUA)

o/c  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE.

To,

The Manager,  
City Convent Sec. School,  
C-19, New Modern Shahdara, Delhi-110032.

Copy to:-

The Dy. Director of Education,  
B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhi.govt.nic.in](http://WWW.dfs.Delhi.govt.nic.in).

2/18

**INSPECTION REPORT**

1. Name & address of the building : City Convent Sec. School, C-19, New Modern, Shahdara, Delhi-110032
2. Building is comprised of : Ground plus two upper floors  
Blocks (A & B)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F 6/DFS/MS/School/2018/NDZ/2099 dated- 13/09/2018
6. Fire Safety direction letter No : Circular No. 262-362 dated 17/01/05
7. Date of Inspection : 09/11/2022
8. Name of the Inspecting officers : DO A.K. Jaiswal & ADO Deepak Kumar
9. Name and designation of Officer from the building side : Sh. AmanChoudhary, Administrator
10. Year of Construction : 1995
11. Applicant's letter no dated 18/07/2022 : Parshantinternational@yahoo.com

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 m N/A N/A	08 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper floor block-A</li> <li>Upper floor block-B</li> <li>Basement</li> </ul>	01 no. 01 no.	02 nos. 02 nos.	MR MR
	b. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor Block-A</li> <li>Upper Floor Block-B</li> <li>Basement</li> </ul>	1.50 m 1.50 m	1.50 m & 0.90 1.05 m & 0.90 m (G+1 <sup>st</sup> ) & 0.78 (1 <sup>st</sup> + 2 <sup>nd</sup> ) iron	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
		01 no.	02 nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A
05	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marked</li> </ul>	06 nos. ABC /CO <sub>2</sub> ISI marked	18 nos. ABC /CO <sub>2</sub> ISI marked	MR MR MR

N/17

N/19

06	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each block at per floor</li> </ul>	01 no.	01 no.	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	30 m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of main panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of repeater panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	➤ Discharge of pump	220 LPM	450 lpm	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	2,500 Ltrs.	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Firemen's grounding switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	N/A	N/A	N/A


P. [Signature]


N/20

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings issued vide letter no F6/DFS/MS/School/2021/NDZ/07 dated 07/01/2022 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule The FSC issued vide letter no F.6 DFS/MS/School/2018/NDZ/2099 dated- 13/09/2018 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.


  
 Signature of the Inspecting Officer  
 Name - A K Jaiswal  
 Designation - D O (ED)

  
 Signature of the Inspecting Officer  
 Name - Deepak Kumar  
 Designation - A D O (Shd)

~~Dy. CFO (NDZ)~~


- Call the explanation from ADO (Shah) as per N/17. with a copy to the U/signed.
- F.T. please


  
 11/11/22

~~DO (ED)~~   
 17/11/2022

~~ADO/Shahd.~~ Sir, fr letter is put up for your kind signature pl.

~~Dy. CFO (NDZ)~~  
 F.T. wing

  
 24/11/22

  
 23/11/2022