

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/2022/School/ND2/1251

Dated: 18/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Delhi University Social Centre Co-ed Secondary School** located at **Block-C, Maurice Nagar, Delhi-110007** comprised of **02 blocks (ground & ground plus first floor only)** owned/ occupied by the **Delhi University Social Centre Co-ed Secondary School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 262-362 dated 17.01.2005 and verified by the officer concerned of Fire Service on **02.11.2022** in the presence of **Mrs. Vibha Sharma (Teacher)** and that the building/premises is fit for occupancy "**Group B Educational**" with effect from **18.11.2022** for a period of three years, subject to compliance of the conditions mentioned below:

Issued on **18/11/2022** at New Delhi


(Atul Garg)
Director

Ph:-011-23414000
o/c

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Delhi University Social Centre Co-ed Secondary School located at Block-C, Maurice Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building	Delhi University Social Centre Co-ed Sec. School at Block-C, Maurice Nagar, Delhi-110007.
2. Type of Occupancy	Educational
3. Composition of building	02 Blocks (Ground & Ground plus first floor only)
4. Type of Case	New Case
5. Details of previous NOC	Nil
6. Fire Safety directives letter No	Nil
7. Date of inspection	02 11 2022
8. Name of the Inspecting Officers	ADO (RN)
9. Name and designation of officers from the building side	Mrs. Vibha Sharma (Teacher)
10. Year of Construction	1989
11. Applicant's letter No	Letter No. DUSCSS 2022-23 2885 dated 11 10 22

	Minimum Standards on fire prevention and fire safety U/R 33	Director. Of Education Circular dated: 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible Directly Accessible NA	Accessible Directly Accessible NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.50m NA	1.40m & 90cm (Iron Staircase) NA	MR (old building) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	01m	1.77m	MR
	f. Door Size	1m	1.25m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	12 a/c per hour 12 a/c per hour	No basement Natural Ventilation	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	08nos	08nos	MR

		ABC Co2	ABC -08	MR
	<ul style="list-style-type: none"> Types ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			MR
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA

2/12

	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	NR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks. if any	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no 2150 dated 18.05.2018.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 17.01.2005, it is recommended to grant Fire Safety Certificate

DO/NW - ON Leave

By CFO (WZ)

Whether the Compliance have been done or not as Communicated C-10.

Signature of the Inspecting Officer
 Name - C.I. Meena
 Designation - ADO RN

R.N
 AA/Ratna

4/11/20

Sir,

As per Dir. of Edu. circular dated 17.1.2005, one staircase requirement 1.5 mtr. But not provided proper width or another staircase .90mtr. as per inspection report staircase width 1.4 mtr. & .90mtr. Full fill the staircase requirement. Cont. P.T.O