

C/60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F6/DFS/MS/2022/WZ/EH/ 318

Dated: 15/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s Euphoria The Sky Lounge A unit of Brothers Wisdom Group, Property No. A-302, North Ex Mall, Sector-9, Rohini, Delhi-85**, is running at 3rd floor in building comprised of **Basement + Ground + 03 upper floors** was inspected by the officer concerned of this department on **14.10.2022** in the presence of **Mr. Gurdeep Dutta** and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy **Group D "Assembly" (Eating House)** for **Property No. A-302, 3rd floor** with effect from 15/11/2022 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/11/2022 at New Delhi by


(Atul Garg)
DIRECTOR
Ph: 011-23414000

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	: M/s Euphoria The Sky Lounge A unit of Brothers Wisdom Group, Property No. A-302, North Ex Mall, Sector-9, Rohini, Delhi-85
2. Type of Occupancy	: Assembly (Eating House) Property No.302, 3rd floor
3. Type of Case	: New Case
4. Details of Previous NOC	: NA
5. Fire Safety directives letter No	: NBC Part IV
6. Date of inspection	: 14.10.2022
7. Name of Inspecting Officer	: A K. Sharma ADO(Rohini)
8. Name and designation of officers From the building side	: Mr. Gurdeep Dutta
9. Year of Construction	: 2000
10. Applicant's letter No.	: Online application no.2022092218025 dated 29.09.2022.

Covered Area-92 sq m

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [North Ex Mall, issued FSC vide letter No.F.6/DFS/MS/WZ/2020/296 dated 05.08.2020]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	c. Protection of exits			
	Fire check door			
	<ul style="list-style-type: none"> • Pressurization 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	d. No. of continuous staircases to terrace			
		Restaurant within mall	As Above	MR
	e. Width of Corridor			
		Restaurant within mall	As Above	MR
	f. Door Size	1.5m	1.60 & 1.5m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Restaurant within mall	As Above	MR
	<ul style="list-style-type: none"> • Upper floors 	Restaurant within mall	As Above	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	One " 300m2	08nos.	MR
		ABC/CO2	ABC/CO2	MR
		ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 near to restaurant	As Above	MR
		30mm	As Above	MR
		5m	As Above	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR

2/6

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
11.	Internal Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	As Above	MR
		One(near to Restaurant)	As Above	MR
		One(near to Restaurant)	As Above	MR
12.	Yard Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	[Provided & Maintained by Mall management]		
		NA	As Above	MR
		NA	As Above	MR
		Required	As Above	MR
		Required	As Above	MR
14.	Captive Water Storage for fire fighting [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
		Restaurant within mall	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Detector System Panel 	NA	NA	NA

2/7

As Above
As Above
As Above
N
MR
MR

	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

on m/Rest
Dytr/fo/w L

CFO
7/11/2022

Director
7/11/22

ADD/fo/w L

FI letter is put up for kind perusal and signature please.

Director
18/11/22

uploaded
23/11/22