



FIRE SAFETY CERTIFICATE

Certified that the **M/s Express Cargo Terminal of Celebi Delhi Cargo Terminal Management India Private Limited** located at **IGI Airport, New Delhi-37**, comprised of Ground + 01 upper floor was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Storage/SZ/2020/07 dated 07/01/2020. The building/premises was re-inspected by a team of officer concerned of this department on 15.11.2022 in the presence of Mr. Ashish Dalal (Fire Safety Officer) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building (**Ground + 01 upper floor**) is fit for occupancy of Group H **"(Storage Building)"** with effect from 24/11/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....24/11/2022.....at New Delhi by

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

o/c

Copy to:-

1. Mr. Sharad Kumar Tijoriya, Head of Quality and safety, Celebi Airport Services India, M/s Express Cargo Terminal of Celebi Delhi Cargo Terminal Management India Private Limited located at IGI Airport, New Delhi-37.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Express Cargo Terminal of Celebi Delhi Cargo Terminal Management India Private Limited located at IGI Airport, New Delhi-37.				
2	Building is comprised of	Ground + 1 upper floor only				
3	Type of occupancy	Group- II (Storage Building)				
4	Type of case	Renewal				
5	Details of previous FSC	F6/DFS/MS/Storage/SZ/2020/07 dated 07.01.2020				
6	Fire safety directive letter no.	F6/DFS/MS/98/BP/380 dated 20.02.1998				
7	Date of inspection	15.11.2022				
8	Name of the inspecting officers	Manoj Sharma, DO (SD) & Rajesh Kumar Shukla, ADO (M Road)				
9	Name of the designation of officer From the building side	Mr. Ashish Dalal (Fire Safety Officer)				
10	Year of construction	1988				
11	Applicant's letter no	Outdoor Diary no 6474 dated 06.10.2022				
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements as per Directive/BBL/NBC	Provide at site	Remarks MR/NMR		
1	Access to Building					
	A	Road width	9.0 mtrs	Provided	MR	
	B	Gate width	5.0 mtrs	Provided	MR	
	C	Width of internal roads	6.0 mtrs	Provided	MR	
2	Number, Width, Type & Arrangement of Exits					
	A	No. of staircase:				
		a)	Upper floor	5 nos.	5 nos	MR
		b)	Basements	NA	NA	NA
	B	Width of the staircase:				
		a)	Upper floors	1.25 mtrs	Provided	MR
		b)	Basements	NA	NA	NA
	C	Protection of Exits				
		a)	Fire check door	NA	Provided	NA
		b)	Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:		NA	NA	NA
	E	Width of the corridor		1.25 mtrs	1.50 mtrs	MR
	F	Door size		1.0 mtrs	1.0 mtrs	MR
3	Compartmentation:					
	A	Fire check doors		Required	Provided	MR
	B	Sealing of horizontal & vertical opening		Required	Provided	MR
	C	Fire rating of shaft doors		NA	NA	NA
	D	Water curtain		NA	NA	NA
	E	Fire dampers		NA	NA	NA
4	Smoke Management System:					
	A	Basements		NA	NA	NA
	B	Upper floors		12 ACPH	Smoke exhaust system (Canopy mounted), manually operated.	MR
5	Fire Extinguishers					
	A	Total numbers		126 nos	126 nos.	MR
	B	Types		CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking		ISI marked	Provided	MR

6	First Aid Hose Reel				
	A	Total no. at each floor	GF = 04 nos 1F = 07 nos	Provided	MR
	B	Length of hose reel	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	6 mm	6 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of detectors	Smoke/heat	Smoke/heat	MR
	B	Location of main Panel	At ground floor	Export CR Ground floor	MR
	C	Location of repeater panel	Required	Import control room	MR
	D	Alternate power source	Required	Provided	MR
	E	Hooter's location	Audible in entire building	Audible in entire building	MR
8	MOEFA				
9	Public Address System				
		Required	Provided	MR	
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Ground & Upper floor	Required	Provided	MR
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	Size of the riser/down comer	150 mm	150 mm	MR
	B	No. of hydrants per floor	GF = 05 nos FF = 08 nos Terrace = 02 nos.	Provided	MR
	C	Hose box	GF = 05 nos FF = 08 nos Terrace = 02 nos	Provided	MR
12	Yard Hydrants				
	A	Total no. of hydrants	04 nos.	Provided	MR
	B	Hose box	04 nos.	Provided	MR
13	Pumping Arrangements (Common Pump House for Export & Import Building)				
	A Ground Level				
		a) Discharge & head of main pump	4500 LPM & 88 m	4500 LPM & 88 m	MR
		b) Number of main pump	02 nos	02 nos	MR
		c) Discharge & head of jockey pump	2 nos of 450 LPM & 88 m each	2 nos of 450 LPM & 88 m each	MR
		d) Discharge & head of Standby pump	4500 LPM & 88 m	4500 LPM & 88 m	MR
		e) Auto starting/ manual stopping	Required	Provided	MR
	B Terrace Level				
		a) Discharge of terrace pump	900 LPM	900 LPM	MR
		b) Head of terrace pump	40 mtrs	40 mtrs	MR
		c) Alternate power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR	
14	Captive Water Storage for Fire Fighting (Common Water Storage for Export & Import Building)				
	A	Underground tank capacity	9,00,000 Ltrs	7,50,000 Ltrs	MR (Old case)
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	10,000 Ltrs	Provided	MR
			Required	Provided	MR
15	Exit Signage				
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply				
		Required	UPS & DG Set	MR	

MW

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire detection system panel	Required	Provided	MR
B	Flow switch panel	Required	Provided	MR
C	P A system panel	Required	Provided	MR
D	Battery backup	Required	Provided	MR
E	Building floor plan	Required	Provided	MR
20	Special Fire Protection for special risk if any			
A	Special fire protection system for protection of special risk, if any:	HVWSS for Transformer & clean agent automatic flooding in HT & LT Panels		MR

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/Storage/SZ/2020/07 dated 07.01.2020 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

msl
 Signature of the Inspecting Officer
 Name Manoj Sharma
 Designation DO (SD)

F.T.

RA
 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

Dy. CFO (SZ) *sh*

ADO (MRA)

FT is put up pls

Dy CFO *sh*

M.S. cell