



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2022/ 1265

Dated: 25/11/2022

FIRE SAFETY CERTIFICATE

Certified that the building of **Govt Co-ed. Sr. Sec. School** Located at **Narang Colony, Tri Nagar, New Delhi -110035** comprised of (Total Five-Block) (Two Blocks comprised of Ground Floor each & Three Blocks comprised of Ground + 1 Upper Floor each) was issued FSC vide letter No. F6/DFS/MS/WZ/2019/2074 dated 29/10/2019. The premises was re inspected by the officer concerned by this department on 10/11/2022 in the presence of **Smt. Dharamvir Singh (Estate Manager)** and observed that fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance DOE circular 3298-3398 dated 17/01/2011 and that the premises is fit for occupancy class "Educational" Group-B, with effect from ..25/11/2022...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on ..25/11/2022... at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. Govt. Co-ed. Sr. Sec. School Located at Narang Colony, Tri Nagar, New Delhi - 110035.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

N-19

1. Name & address of the building: Govt. Co-ed Sr. Sec. School Located at Narang Colony, Tri Nagar, New Delhi – 110035.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/WZ/2019/2074 dated 29/10/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 10/11/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO(MN)
8. Name and designation of officers from the building side : Smt. Dharamvir Singh (Estate Manager)
9. Year of Construction : 1998 (As Per Prev. Insp. Report dated: - 18/10/2019)
10. Applicant's letter No. : Email dated 13/10/2022

* The said school is comprised of (Total Five- Block) (Two Blocks comprised of G. Floor each & Three Blocks comprised of Ground + 01 upper floor each)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011 As Per Pre. Insp. Report dtd:- 18/10/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mts Accessible NA	Provided 5 mtr Provided NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	Block A & B= Ground floor only Block C = 02 Block D = 01 Block E = 03	MR (Old Case)
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases	1.5 mts	Block C = 150 & 146cm Block D = 154 cm Block E = 2x155 & 1x144cm	MR
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 m	154 cm Provided	MR
	g. Door Size	1 mts	105 cms provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	18 nos. CO ₂ , ABC type	Provided Provided	MR MR

SV

		ISI marked	Provided	MR
	<ul style="list-style-type: none"> IS marking 			
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	Required	Provided	MR

2/20

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/MN/2022/624 dated 03/10/2022 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F.6/DFS/MS/WZ/2019/2074 dated 29/10/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (West)~~

[Signature]
 Signature of the Inspecting Officer
 Name: Sarabjeet Singh
 Designation: ADO (MN)

367/ADO/MN
 14/11/2022

[Signature]
 14/11/2022

D.O. (WEST) 351
 DATED 14/11/2022

~~DO (WZ)~~

[Signature]
 15/11/22

~~ADO (MN)~~

Sir, F.T is put up for your kind personal & signature please.

~~DO (WZ)~~

[Signature]
 17/11/2022

[Signature]
 20/11/22

MS cell