

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2022/ 522

Dated: 23/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Indraprastha Merto Station (Except PD area)** at New Delhi comprised of ground, concourse and platform was granted FSC by this department vide letter No. F6/DFS/MS/NDZ//2019/1731 dated 05/09/19. The premises was re-inspected by the officer concerned of this department on 07/11/2022 in the presence of Mr. Kumar Vaibhav (AM/Fire) and found that the said Metro Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D (**Assembly Metro Railway**) with effect from 23/11/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/11/2022 at New Delhi by.


(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

- 1) Sh. Vivek Shrivastav JGM /E&M,
Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

11/19

INSPECTION REPORT

1. Name & address of the building : Indraprastha Merto Station New Delhi
2. Type of Occupancy : Assembly building (D7as Per NBC Part IV 2005)
3. Type of Case : Renewal
4. Details of previous FSC : F6/DFS/MS/NDZ/2019/1731 dated 05/09/19.
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2005/2239 dated 26/10/2015
6. Date of inspection : 07/11/2022.
7. Name of the Inspecting Officer : A.D.O Ravinder Singh
D.O. Rajinder Atwal
8. Name and designation of Officer
from the building side : Mr. Kumar Vaibhav (AM/Fire)
9. Year of Construction : 2006
10. Applicant's letter No. : firewingblue@gmail.com dated 19/09/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Required	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	6 mtr.	Provided	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	Ground to Concourse - 2, Concourse to Platform - 2	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	03 mtr. each	Provided	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Fire curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A



	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	30 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	2 Nos.	2 Nos.	MR
	2) Length of hose reel hose	30 mtr.	36 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Required	Provided in station control room	MR
	3) Location of repeater panel	Required	Provided at concourse level	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided at station control room & at all levels	MR
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required 100 mm.	100 mm.	MR
	2) Number of hydrants per floor	Required	Provided at Ground level-1, at concourse level-1 at platform level-4 Nos.	MR
	3) Hose box per floor	Required	6 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1800 LPM	Provided	MR
	b) Head of main pump	70 mtr.	Provided	MR
	c) Number of main pump	2 No.	Provided	MR
	d) Jockey pump out put	180 LPM	Provided	MR
	e) Jockey pump head	70 mtr.	Provided	MR
	f) Stand by pump output	1800 LPM	Provided	MR
	g) Stand by pump head	70 mtr.	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	1,00,000 ltrs.	1,00,000 ltrs.	MR

	a) Draw-off connection	Required 01	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Co ₂ flooding system provided in HT/LT panel			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/DMRC/NDZ/2019/1731 dated 05/09/19 under rule 35 of the Delhi Fire Service rules 2010. Accordingly reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer



Name :- Rajinder Atwal
Designation :- DO (CD)



Name :- Ravinder Singh
Designation :- ADO (CC)

~~Dy. Insp. (CD)~~

F.T. pl.



ADO (CC)

As approved and put up for kind perusal and signature please

~~Dy. Insp. (CD)~~



F.P wing

