

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**


No.F.6/DFS/MS/School/2022/SZ/1244

Dated: 17/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **M.C Primary School**, Issa Pur, New Delhi-110073 comprised of ground plus one upper floor, having total 09 rooms (Including Class Rooms, Hall & Office etc.) owned/occupied by M.C primary school was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2017/SZ/445 dated 24/03/2017. The school building was re-inspected by the officer concerned of this department on 02/11/2017 in the presence of Sh. Lalit Kumar (Principal) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class 'Educational' w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on 17/11/2022 at New Delhi.


(SUNIL CHAWDHARY)
DY.CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
M.C Primary School,
Issa Pur, New Delhi-110073
2. Director of Education,
Civic Centre, Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/10

INSPECTION REPORT

1	Name & address of the building	M C Primary School, Issa Pur, New Delhi-110073
2	Building comprised of	Ground plus one upper floor
3	Type of Occupancy	Educational
4	Type of Case	Renewal
5	Details of Previous NOC	F 6/DFS/MS/School/2017/SZ/445 dated 24/03/2017
6	Fire Safety directives letter No	Circular No F 16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01 03 2011
7	Date of inspection	02/11/2022
8	Name of Inspecting Officer	A D O R K Yadav
9	Name and designation of officers	Sh Lalit Kumar (Principal)
10	Year of Construction	2008-09
11	Applicant's letter No	Form "J" dated 21/10/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 24.03.2017	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs N/A N/A	09 mtrs N/A N/A	MR N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s N/A	02 no.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & .75 m N/A	1.68 & .92 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		1.50 m	2.20 m	MR
	f. Door Size			
		Old case	.95 m	MR, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural Ventilation provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 No's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

N/12

Fire Control Room

<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2017/SZ/445 dated 24/03/2017 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
7/11/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

The noting has not been signed by the
Concern ADO

Dycho (S2)
ADG
9/11/22

ADO/VKB

FT letter & put up for signature

DYCHO/S2
su
M.S-Cell
R.K.
14/11/2022