

7-36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6 DFS/MS/School/2022/SZ/1270

Dated: 25/11/2022

**FIRE SAFETY CERTIFICATE**

Certified that **Mother Teresa C.B. Sr. Sec. School, Uri Enclave, Delhi Cantt, New Delhi-110010** comprised of Ground plus Two upper floors owned/occupied by Delhi Cantonment Board have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concern of this department on 13/11/2022 in the presence of Smt. Sunita (HOS) and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from 25/11/2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/11/2022 at New Delhi by

  
**(ATUL GARG)**  
**DIRECTOR**

Copy to: -

1. The Assistant Engineer (E &M) Delhi Cantonment Board, Sadar Bazar, Delhi Cantt. 10

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1. Name & address of the building: **Mother Teresa C.B. Sec. Sec. School, Uri Enclave, Delhi Cantt, New Delhi-110010.**
2. Type of Occupancy : Educational (New Building)
3. Type of Case : New
4. Details of previous NOC : Nil Ground + Two Upper Floors
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 13/11/2022
7. Name of the Inspecting Officer : A.D.O. (BCP)
8. Name and designation of Officer from the building side : Smt. Sunita (HOS)
9. Year of Construction : 2019-20
10. Applicant's letter No. DCB/8/C/Engg./School/Fire/2022-23 dated 19/09/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC / Doe Cir. 11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.50 mtr	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	Provided	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
	• ISI marking	Required	Provided	MR

6	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR



15.	Exit Signage	N/A	Required	Provided	MR
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	N/A		N/A	N/A
	➤ Pressurization of lift lobby	N/A		N/A	N/A
	➤ Communication in lift Car	N/A		N/A	N/A
	➤ Fireman's Grounding Switch	N/A		N/A	N/A
	➤ Lift Signage	N/A		N/A	N/A
17.	Standby power supply	N/A		N/A	N/A
18.	Refuge Area	N/A		N/A	
	➤ Total area	N/A		N/A	N/A
	➤ Location	N/A		N/A	N/A
19.	Fire control room				
	➤ Detector system panel	N/A		N/A	N/A
	➤ Flow Switch Panel	N/A		N/A	N/A
	➤ PA System Panel	N/A		N/A	N/A
	➤ Battery backup	N/A		N/A	N/A
	➤ Building Floor Plans	N/A		N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A		N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 326 dated 02/07/2021

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD)

*Handwritten signature*  
14/11

*Handwritten signature*  
(S2)

*Handwritten signature*  
C. A. O.  
11/11/2021  
*Handwritten signature*  
21/11/21  
*Handwritten signature*  
21/11/21

*Handwritten signature*  
Anup