

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/DFS/MS/2022/ Hospital/ 517

Dated: 21 / 11 /2022

FIRE SAFETY CERTIFICATE

Certified that the **Vinayak Hospital** located at **Derawal Nagar, Model Town, Delhi-110009** comprised of **Basement, Ground & 03 upper floors Only** owned/ occupied by **Vinayak Hospital** have complied with the Fire Prevention and Fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on **16.11.2022** in the presence of **Sh. Naresh Kr. Aggarwal (Management)** and that the building/ premise is fit for occupancy class **Institutional "Group C"** with effect from 21/11/2022 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 21/11/2022 at New Delhi

(A. M. Garg)
Director

Ph:-011-23414000

Copy to :

1. The Chairmen, Vinayak Hospital located at Derawal nagar, Model Town, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. The Terrace shall be not used for any hospital purpose.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Vinayak Hospital at Derawal Nagar, Model Town, Delhi-09
2. Type of Occupancy : Institutional
3. Type of Case : New Case
4. Composition of building : Basement, Ground & 03 upper floors only
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F.6/DFS/MS/BP Hospital/2022/1711 dated 12.07.2022
7. Date of inspection : 16.11.2022
8. Name of the Inspecting Officers : ADO/RN
9. Name and designation of officers from the building side : Sh. Naresh Kr. Aggarwal (Management)
10. Year of Construction : --
11. Applicant's letter No. : Online E-Mail ID dated 14.11.2022

Total Plot Area- 620Sqm

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBI Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	18m	18m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	03	MR
	b. Width of staircases			
	• Upper Floors	2m & 1.5m	02m & 1.5m	MR
	• Basements	2m & 1.5m	02m, 1.5m & 85cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	2.40m	Provided	MR
	f. Door Size	1.25m ward 02m I.C.U	1.25cm ward 02m I.C.U	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	12ACPH	Provided	MR
	• Upper floors	12ACPH	Provided	MR
5	Fire Extinguishers			

	• Total numbers	26 nos	30nos	MR
	• Types	ABC Co2	ABC-20/ Co2-10	MR
	• IS marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01at each floor	01 at each floor	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat/Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Ground floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Every floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down-comer	63mm	63mm	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants.			
	• Total number of hydrants	01	01	MR
	• Hose Box	01	01	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	➤ Discharge of main Pump	1620 LPM	1620 LPM	MR
	➤ Head of Main pump	40mtr	40mtr	MR
	➤ Number of main pumps	02	02	MR
	➤ Jockey Pump out put	180 LPM x2	180 LPM x2	MR
	➤ Jockey pump head	40mtr	40mtr	MR
	➤ Standby Pump out put	1620 LPM	1620 LPM	MR
	➤ Standby Pump Head	(Diesel engine)	(Diesel engine)	
	➤ Auto Starting/ Manual stopping	40mtr	40m	MR
		Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	1620 LPM	1620 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	75,000lrs	75,000lrs	MIR
	➤ Draw-off connection	Required	Provided	MIR
	➤ Fire service inlet	Required	Provided	MIR
	➤ Access to tank	Required	Provided	MIR
	• Overhead Tank capacity	10,000ltr	10,000ltr	MIR
15	Exit Signage.			
		Required	Provided	MIR
16	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	Required	Provided	MIR
	➤ Pressurization of Lift lobby	Required	Provided	MIR
	➤ Communication In lift Car	Required	Provided	MIR
	➤ Fireman's Grounding Switch	Required	Provided	MIR
	➤ Lift Signage	Required	Provided	MIR
17	Standby power supply			
		Required	Provided	MIR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		Required	Provided	MIR

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection. The management has complied all the observations which were communicated vide this department letter of even no. 2806 dated 11.11.2022.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

DO/NW - ON MIRest

Dy. FSO (WZ)

DoF SW is available.

Signature of the Inspecting Officer

Name: - C. L. Meena

Designation: - ADO RN

DO/SW)

W 16/11/22

Recommended for issuance of FSC under Rule 35 of DFS Rules 2010 12/11/22

17/11/22