

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2022/SZ/ 533

Dated: 29/11/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Anubhav Community Hall running at ground & first floor in a building comprised of basement, ground plus two upper floors at CH-6, J-Block, Vikas Puri, New Delhi was granted NOC vide letter No. F.6/DFS/MS/09/1717 dated 10.06.09 for occupancy of the building, owned/occupied by M/s Arorbans Sabha (Regd.). The premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 07/11/2022 in the presence of Sh. Harish Pandey (Manager) of the Banquet Hall and found that the building (ground & first floor only) is fit for occupancy class "D" 'Assembly Building' with effect from 29/11/2022 for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed below.

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

To,

Sh. Harish Pandey (Manager), M/s Anubhav Community Hall at CH-6, J-Block, Vikas Puri, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Anubhav Community Hall, CH-6, J-Block, Vikas Puri, New Delhi
2. Building comprised of : Basement, ground plus two upper floors (2nd floor not in use)
3. Type of Occupancy : Assembly Building.
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/09/1717 dated 10.06.09
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2005/1299 dated 17.06.2005 & F.6/DFS/MS/2008/1832 dated 01.07.08
7. Date of inspection : 07/11/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Harish Pandey (Manager)
10. Year of Construction : Before 2009
11. Applicant's letter No. : Nil dated 08/10/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs. 05 mtrs. N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	M/R
	• Basements	Two	Two	M/R
	b. Width of staircases			
	• Upper Floor	1.50 & 1.25 m	1.50 & 1.25 m	M/R
	• Basements	1.50m	2x1.5 m & 1x1.20 m	M/R
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m	2 m & 1.5 m & 1.0 m on GF, 2 M & 1.5 M on FF	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	M/R N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required Required	Provided Provided	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 no.'s ABC & CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R

Basement use as storage purpose, ground & first floor use for banquet hall & second floor not in use.

M17

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One	Provided	M/R
		36 mtrs.	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
<ul style="list-style-type: none"> Basement Ground & First Floor Sprinkler above false ceiling 	Required	Provided	M/R	
	Required	NP	M/R old accepted	
	N/A	N/A	N/A	
11.	Internal Hydrants			
<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR	
	One	Provided	M/R	
	One	Provided	M/R	
12.	Yard Hydrants			
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A	
	N/A	N/A	N/A	
13.	Pumping Arrangements			
<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	1620 LPM	Provided	M/R	
	55 mtrs.	Provided	M/R	
	One	Provided	M/R	
	180 LPM	Provided	M/R	
	55 mtrs.	Provided	M/R	
	1620 LPM	Provided	M/R	
	55 mtrs.	Provided	M/R	
	Required	Provided	M/R	
	Required	Provided	M/R	
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	Provided	M/R
30 Mtrs		Provided	M/R	
Required		Provided	M/R	
Required		Provided	M/R	
14.	Captive Water Storage for fire fighting			
<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50000 ltrs	Provided	M/R	
	Required	Provided	M/R	
	Required	Provided	M/R	
	Required	Provided	M/R	
	10,000 Ltrs.	Provided	M/R	
15.	Exit Signage.	Required	Provided	M/R

Guidelines was issued vide letter No. F6/DFS/MS/BP/2005/299 dated 17/06/2009 but previous NOC was issued vide letter No. F6/DFS/MS/09/1717 dated 10/06/2009 with out sprinklers system for upper floors.

Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection. The shortcoming issued vide letter No. F6/DFS/MS/Assembly/2019/SZ/5746 Dated 23/09/2019 has been complied.

In view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/09/1717 dated 10.06.09 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The staircase requirement of 1.50 M (02 no.'s) has been accepted as 1.50 M and 1.25 M being fate accompli in previous NOC dated 10.06.2009. There is no mention of basement in previous NOC although as per the guidelines issued by this department vide letter dated 17.06.2005 has mention of basement.

R. K. Yadav
21/11/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

DO(SW)
21/11/22

Dyefo (S2)

F. I -
[Signature]

ADAR D
FT letter to put up fire sign plan
DYCFOSD
21/11/22

MS-CP