



C-43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव


No. F6/DFS/MS/School/WZ/2022/ 1271

Dated: 28/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Abhinav Public School** located at CU- Block, Pitampura, Delhi- 110088, **running at Basement, Ground plus three upper floors** in a building comprised of Basement, Ground plus Four Upper Floor, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/WZ/School/2019/2073 dated 29.10.2019. The school building was re-inspected by the officer concerned of this department on 18.11.2022 in the presence of Ms. Manju Dhingra and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with NBC-IV and that the premises/building is fit for occupancy class "Educational Building" Group B (**Basement, Ground plus Three Upper Floor Only**) with effect from 28/11/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 28/11/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Directorate of Education, GNCT of Delhi, Old Secretariat Delhi 54.- **with the request to make sure that 4th Floor must not be used for any purposes**
2. The Principal, Abhinav Public School, CU- Block, Pitampura, Delhi- 110088.
3. The commissioner, Municipal Corporation of Delhi , Civic Centre, Minot Road, New Delhi :- **with the request to make sure that 4th Floor must not be used for any purposes**



Following fire safety directives must be adhered to: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. This FSC is valid for Basement, ground, first, second & third floor only. The 4th floor shall not be used for any purposes and if it is used in future, FSC shall be null & void

2/17

INSPECTION REPORT

1. Name & address of the building : Abhinav Public School, CU-Block, Pitampura, New Delhi.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/School/2019/2073 dated 29.10.2019
5. Fire Safety directives letter No : F.6/DFS/MS/BP/99/1611 dated 25.11.1999
6. Date of inspection : 18.11.2022
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO (West)
8. Name and designation of officers from the building side : Sh. Manju Dhingra, Principal
9. Year of Construction : 2004
10. Applicant's letter No. : APS/Fire/2022-23 dated 16.10.2022

The school is running at Basement, ground, first, second & third floor in a building comprised of basement, ground plus four upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR									
1	Access to building												
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr><td>Accessible</td><td>7.0 mts Provided</td><td>MR</td></tr> <tr><td>Accessible</td><td>5.50 mts Provided</td><td>MR</td></tr> <tr><td>N/A</td><td>N/A</td><td>N/A</td></tr> </table>	Accessible	7.0 mts Provided	MR	Accessible	5.50 mts Provided	MR	N/A	N/A	N/A		
Accessible	7.0 mts Provided	MR											
Accessible	5.50 mts Provided	MR											
N/A	N/A	N/A											
2	Number, Width, Type & Arrangement of Exits												
	a. Number of staircases	-----	-----	-----									
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 mts	02	MR									
	b. Width of staircases	-----	-----	-----									
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mts each	1.80 mts x 02 nos.	MR being old case									
	c. Protection of exits	-----	-----	-----									
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	1.5, 1.0 mts	01 x 1.80 mts, 02 x 1.47 mts	MR being old case									
	e. No. of continuous staircases to terrace	-----	-----	-----									
	g. Width of Corridor	N/A	N/A	N/A									
	h. Door Size	N/A	N/A	N/A									
		01	01	MR									
		1.5 mts	Provided	MR									
		1.0 mt.	Provided (1.15 mts)	MR									
3	Compartmentation.												
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
		N/A	N/A	N/A									
4	Smoke Management System.												
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided	MR									
		12 a/c per hour	N/A	N/A									
5	Fire Extinguishers												
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	32 nos.	Provided	MR									
		ABC, CO ₂ type	Provided	MR									
		ISI marked	Provided	MR									

2/15

Standby p
Refuge Area
Total
18
19
Fire

6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13	Pumping Arrangements			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	---	-----	-----
	➤ Discharge of pump	900 , 450 LPM	Provided	MR
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	---
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A


3

7	Standby power supply	N/A	N/A	N/A
8	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the renewal of the NOC issued vide letter No. F6/DFS/MS/WZ/School/2019/2073 dated 29.10.2019, is recommended.

Accordingly DFA is put up for approval & signature please.


22/11/2022

Signature of the Inspecting Officer
Divisional Officer (West Division)


520/50/WZ
DFA - 22/11/2022


~~DCFO (WZ)~~

22/11/2022

~~DCFO (WZ)~~

F.T. letter is put up for Sign. please

~~DCFO (WZ)~~


24/11/2022


28/11/2022

msceef