

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI**

No: F6/DFS/MS/School/WZ/2022 | 1239

Dated: 16/11/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Nigam Prathibha Vidyalaya No. 1**, located at **Ramesh Nagar, New Delhi – 110015. (School ID- 1556154)** comprised one block (Ground plus One Upper floor), Owned/Occupier by **Nigam Prathibha Vidyalaya No. 1** was issued FSC vide letter No. F6/DFS/MS/School/WZ/2019/1355 Dated: 28/06/2019. The premises was re-inspected by the officer concerned by this department on 01/11/2022 in the presence of Ms. Chander (Incharge) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention & fire safety requirements in accordance with Circular No. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 issued by the Directorate of education and found that the premises is fit for occupancy class "Educational" Group B with effect from 16/11/2022 for a period of three years subject to the compliance of the conditions mentioned below:-

Issued on 16/11/2022 at New Delhi.

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer,  
Delhi Fire Service

Copy to:

1. The Principal/Incharge, Nigam Prathibha Balika Vidyalaya No.1 Located at Ramesh Nagar, New Delhi – 110015. **(School ID- 1556154)**.
2. Director of Education, Old Sectt. Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Balika Vidyalaya No.1 Located at Ramesh Nagar, New Delhi-110015. **(School ID- 1556154)**
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2019/1355 Dated: 28/06/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 01/11/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of officers from the building side : Ms. Chander (Incharge)
9. Year of Construction : 1959 (As Per Prev. Insp. report dated 17/06/2019)
10. Applicant's letter No. : Outdoor Diary letter No. 6069 dated 26/09/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular dated 01/03/2011/ As Per Prev. Insp. report dated 17/06/2019	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mts	1x150cm & 1x114cm	MR (old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	02	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1 mts (Class Room)	110 cm Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A



5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	05 nos.	Provided	MR
		CO <sub>2</sub> , ABC type	Provided	MR
		ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	NR	NR	NR
	Length of hose reel hose	NR	NR	NR
	Nozzle diameter	NR	NR	NR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	Basement	N/A	N/A	N/A
	Upper Floor	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-comer	N/A	N/A	N/A
	Number of hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	➤ Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A

4	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2022/524 dated 05/09/2022 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/School/WZ/2019/1355 Dated: 28/06/2019 renewal under DOE Circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Directorate of Education, Govt. OF NCT of Delhi, is recommended.

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADOMN)

DO (West)

352/ADD/MN  
04/11/2022

DO WEST/23  
DATED 8/11/2022

8/11

ADD/MN

888  
04/11/2022

9/11/2022