

C-22
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No.F.6/DFS/MS/School/2022/SZ/ 1273

Dated: 28/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Professor's Global School, Baprola, (Najafgarh-Nangloi Road) Delhi-110043**, comprised of 1st block (ground plus one upper floors) & 2nd block (ground plus two upper floors), owned/occupied by Professor's Global School was issued FSC vide letter No. **F.6/DFS/MS/School/2019/SZ/1639 dated 19/08/2019**. The school building was re-inspected by the officer concerned of this department on dated 18/11/2022 in the presence of Smt. Pooja Chhabra (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....28/11/2022.....at New Delhi by



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Principal,
Professor's Global School, Baprola,
(Najafgarh-Nangloi Road) Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. In case of usage of third floor for schooling purpose then this FSC will be null and void.

INSPECTION REPORT

- Name & address of the building : Professor's Global School, Baprola, (Najafgarh-Nangloi Road) Delhi-110043.
- Building is comprised of : 2 Blocks (A block having G+1 & B block having G+2 floors)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2019/SZ/1639 dated 19/08/2019
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 18/11/2022
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Pooja Chhabra (Principal)
10. Year of Construction : 2017-18
11. Applicant's letter No. : PGS/22-23/508 dated 05/08/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m 4.5 m N/A	Provided 4.5 M N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 No's in each blk	01 No.(G+1) 02 No.(G+2) blk	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m N/A	1.50 & 1.0 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	One	one	MR
	e. Width of Corridor	1.50 m	2.5 m (G+1) 2.0 M (G+2)	MR
	f. Class room Door Size	1.0 m	1.0 m (G+1) 1.25 M X2	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R

Exit Signage.
Provision of Lifts
Press

6.	First-Aid Hose Reels	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A	N/A
8.	MOEFA		N/A	N/A	N/A
9.	Public Address System		N/A	N/A	N/A
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A	N/A
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A	N/A
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A	N/A
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A	N/A
		450 LPM in G+2 blk.	Provided	MR	
		40 m	Provided	MR	
		Required	Provided	MR	
		Required	Provided	MR	
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity in G+2 block 	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A
		N/A	Provided	N/A	N/A
		N/A	N/A	N/A	N/A
		10,000 ltrs	Provided	MR	

✓

Signage.	Required	Provided	MR
Provision of Lifts.			
			(No Lift)
• Pressurization of Lift Shaft	N/A	N/A	N/A
• Pressurization of Lift lobby	N/A	N/A	N/A
• Communication In lift Car	N/A	N/A	N/A
• Fireman's Grounding Switch	N/A	N/A	N/A
• Lift Signage	N/A	N/A	N/A
17. Standby power supply	N/A	N/A	N/A
18. Refuge Area.			
➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
19. Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Battery backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2019/SZ/1639 dated 19/08/2019 renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav

Signature of Inspecting Officer ^{21/11/2022}
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

D.O. (South West) *[Signature]*
 22/11/22

Dyefo (SZ)

[Signature]
 E/-

ADD (RT)
 FT letter is put up for review
[Signature]
 24/11/2022
 Dyefo (SZ)

m.s. - cell