



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE **NEW DELHI-110001**

No.F.6 DFS/MS/School/2022/SZ/ 1254

Dated: 23/ 11/2022

## FIRE SAFETY CERTIFICATE

Certified that RCCE Public School, situated at 265/2, Chandan Hulla New Delhi 110074 comprised of Ground plus Three Upper Floors owned/occupied by RCCE Public School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2020/SZ/84 dated 02/03/2020. The said premises was re-inspected by officer concerned of this department on 17/11/2022 in presence of Mr. Rajender Kumar Saini (Manager) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group – B" with effect from 23/11/2022 for a period of Three years in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 23/11. 2022 at New Delhi by

## (SUNIL CHAWDHARY) **DY. CHIEF FIRE OFFICER (SZ)**

Copy to: -

- py to: -1. The Principal, RCCE Public School, situated at 265/2, Chandan Hulla New Delhi 110074.
- 2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

## **Conditions for the validity of Fire Safety Certificate**

- 1. All the means of escape/entry/exit shall be kept free from any obstruction.
- 2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3. All the staff members must know the correct method of operation of firefighting system.
- 4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N112



-	INSPECT	ION DES		ਗਾੜੀ ਮੁਸੁਰ ਸੋਫ਼ੀ		
	INSPECTION REPORT Name & Address of the Building RCCE Public Sciences					
-		RCCE Public School, at 265/2, Chandan Hulla New				
3	Type of Occupancy	Demi 110074				
4	Building Comprised of	Ground + 03 upper floors       etails of Previous NOC     Renewal       re Safety Directives Letter No     F6/DFS/MS/School/2020/SZ/84 dated 02/03/2020       ate of Inspection     F16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.20       ame of the Inspecting Officers     Sh. Rajesh Kumar ADO (BCP)				
5	Type of Case					
6	Details of Previous NOC					
7	Fire Safety Directives Letter No					
8	Date of inspection					
0	Name of the Inspecting Officers					
7	Name & Designation of Officer					
10	non me building side	Mr. Rajender Kumar Saini 1992				
11	Year of construction					
S. No.	Applicant letter No.		Dated 31/10/2022			
5. 10,	stalluards on king D	OLD NOC	Provided at Site	Remar		
1	and The Salety U/R 33	requirements		MR/NM		
	Access to Building.	induction in the second s				
	Road width	Accessible	06 mtr	MR		
	• Gate width	-NA-	4.5 mtr	-NA-		
2	Width of internal road	-NA-	-NA-	-NA-		
4	Number, width, type & arrangement of ex	its.				
	a) rumber of Staircase					
	Upper floors.	01 No	02 mtr	MR		
	Basement floor.	-NA-	-NA-	-NA-		
	b) Width of Staircase		1.1.1			
	Upper floors	1.5m/0.75m	1.50 mtr & 1.0 m	MR		
	Basement floor	-NA-	-NA-	-NA-		
	c) Protection of exits					
	Fire check door	-NA-	-NA-	-NA-		
	Pressurization	-NA-	-NA-	-NA-		
	d) No. of continuous staircase to terrace	One	Provided	MR		
	e) Width of corridor	-NA-	-NA-	-NA-		
	f) Door size	01 mtr	01 mtr	MR		
3	Compartmentation.	or mu	01 mu	MIK		
	Fire check door.	-NA-	-NA-	NIA		
	<ul> <li>Sealing of electrical shafts.</li> </ul>	-NA-	-NA- -NA-	-NA- -NA-		
	<ul> <li>Fire rating of shaft door.</li> </ul>	-NA-	-NA-	-NA-		
	Water curtain	-NA-	-NA-	-NA-		
	<ul> <li>Fire dampers.</li> </ul>	-NA-	-NA-	-NA-		
4.	Smoke Management system.			11/3-		
	• Basement	-NA-	-NA-	-NA-		
	• Upper floors	12 APCH	Natural ventilation	MR		
5.	Fire Extinguishers.		Simulon	WIK		
	Total numbers	12 Nos	14 Nos	MR		
	• Types	ABC / CO2	ABC & Co2	MR MR		
	ISI Marking	ISI mark	Provided	MR MR		
6.	First Aid Hose Reels.		Tonded	MK		
	<ul> <li>Total numbers on each floor.</li> </ul>	02 No	Provided	MD		
	Length of hose-reel hose	30m	Provided	MR		
	Nozzle Diameter	5mm		MR		
-	Automatic fire detection & alarming system.	511011	Provided	MR		
7						

	<ul> <li>Location of Main Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Alternate source of power</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul> <li>Basement</li> </ul>	-NA-	-NA-	-NA-
	Upper floors	-NA-	-NA-	-NA-
	<ul> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul> <li>Size of Riser/Down-comer</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Number of Hydrant per floor</li> </ul>	-NA-	-NA-	-NA-
	Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul> <li>Total number of hydrants.</li> </ul>	-NA-	-NA-	-NA-
	Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	-NA-	-NA-	-NA-
	Head of main pump.	-NA-	-NA-	-NA-
	Number of main pumps.	-NA-	-NA-	-NA-
	Jockey Pump output.	-NA-	-NA-	-NA-
	Jockey Pump head.	-NA-	-NA-	-NA-
	Standby Pump output.	-NA-	-NA-	-NA-
	Standby Pump head.	-NA-	-NA-	-NA-
	<ul> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	Terrace Level			
	Discharge of pump.	450 LPM	Provided	MR
	Head of pump.	40 M	Provided	MR
	Power supply.	Required	Provided	MR
14	> Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul> <li>Underground tank capacity.</li> <li>Draw-off connection</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Access to tank.</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
15.	Exit Signage.	10,000 ltrs	Provided	MR
16.	Provision of Lifts.	Required	Provided	MR
	Pressurization of lift shaft.	NA		
	<ul> <li>Pressurization of lift lobby.</li> </ul>	-NA- -NA-	-NA-	-NA-
	<ul> <li>Communication in lift car.</li> </ul>		-NA-	-NA-
	<ul> <li>Fireman's switch.</li> </ul>	-NA- -NA-	-NA-	-NA-
	<ul> <li>Lift signage.</li> </ul>		-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area	-NA-	-NA-	-NA-
-	Total area	NA		
	Location	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

n

महोत्स

NIIY



19.	Fire Control Room.			
	Detector system panel.	-NA-	-NA-	-NA-
	<ul> <li>Flow switch panel.</li> </ul>	-NA-	-NA-	-NA-
	• PA system panel	-NA-	-NA-	-NA-
	<ul> <li>Battery backup.</li> </ul>	-NA-	-NA-	-NA-
	<ul> <li>Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2020/SZ/84 dated 02/03/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Berlan /

-NA--NA--NA--NA M

Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)

DO (SD) mish Defo (SX ts approved F.T. Letter is putting for me synature Pl Dy choller