

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2022/ 1283

Dated: 30 / 11 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Boys Secondary School** located at E-Block Kamla Nagar, Delhi-110007 comprised of **Ground and first floor** owned/occupied by **Govt. Boys Secondary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/SCHOOL/2019/1965** dated **15.10.2019**. The premises was re-inspected by the officer concerned of this department on **15.11.2022** in presence of **Sh. Bhagwan Das (Vice Principal)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from 30/11/2022 for a period of three years, subject to compliance of the conditions mentioned below.

Issued on 30/11/2022 at New Delhi by.


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Govt. Boys Sec. School located at E-Block, Kamla Nagar, Delhi -110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Govt. Boys Secondary School located at E-Block Kamla Nagar, Delhi-110007.
2. Type of Occupancy : Educational
3. Composition of building : One block (Ground & first floor only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/1965 dated: 15.10.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 15.11.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Bhagwan Das (Vice Principal)
10. Year of Construction : 2007
11. Applicant's letter No. : Online E-mail Dated: 21.10.2022

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education requirements 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building	Accessible	Accessible	MR
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01	02	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m	1.60m & 1.25m	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	2.45m	MR
	f. Door Size	1 m	1.05m	MR
	3	Compartmentation.	NA	NA
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA
• Fire Rating of shaft door		NA	NA	NA
• Water Curtain		NA	NA	NA
• Fire Dampers		NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	06nos	23nos	MR
	• Types	ABC/Co2	ABC—19/Co2--04	MR
	• ISI marking	ISI Marked	Yes	MR

f

6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
8	MOEFA			
	NA	NA	NA	
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
12	Yard Hydrants.			
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	N/A	NA
➤ Head of the pump	NA	N/A	NA	
➤ Power Supply	N/A	N/A	N/A	
➤ Auto Starting of pump	N/A	N/A	N/A	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	N/A	NA	

11/15

15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 1965 dated: 15.10.2019.

DO/NW - ON m/Rest


~~DO/CFD (WZ)~~


~~DO/SW~~

~~17/11/22~~
~~DO/CFD (WZ)~~
~~16/11/22~~
~~23/11/22~~

~~ADO/RN~~

As per approved, F.T. letter is set up for your signature pl.


 Signature of the Inspecting Officer
 Name: - C.L. Meena
 Designation: - ADO/RN


 24/11/2022
 cont