



C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/NDZ/1285

Dated: 30 / 11 / 2022

FIRE SAFETY CERTIFICATE

Certified that The Samarth School (Earlier it was Siddharth International Public School), located at Opp. Pocket- B, East Loni Road, Delhi-110093, comprised of Ground + Three Upper Floors only owned / occupied by The Samarth School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/2052 Dated 25/10/19. The School building was re-inspected by the officer concerned of this department on 16/11/2022 in presence of Sh. Rajnish Gupta (Administrator) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E. Circular No. 262-362 Dated 17/01/2005 and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 30 / 11 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30 / 11 / 2022 at New Delhi by.


(S.K.DUA)

**Dy. CHIEF FIRE OFFICER.
DELHI FIRE SERVICE**

Copy to :-

1. The Principal, The Samarth School (Earlier it was Siddharth International Public School), Opp. Pocket- B, East Loni Road, Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-11053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: The Samarth School, (Earlier it was Siddharth International Public School)
Opp. Pocket- B, East Loni Road, Delhi-110093
2. Building Comprised of : Ground + Three upper Floors only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2019/NDZ/2052 Dt. 25/10/19
6. Fire Safety directives Letter No.: D.O.E. Circular No. 262-362 Dated 17/01/2005
7. Date of inspection : 16/11/2022
8. Name of the Inspecting Officer : D.O. (E.D.)
9. Name and designation of Officer
from the building side : Sh. Rajnish Gupta (Administrator)
10. Year of Construction : 1996

11. Applicant's letter received through email dated 14/11/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	4.50 mtr	4.70 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.35 mtr	MR (old accepted)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 mtr	1.60 mtr	MR
	f. Door Size	1.00 mtr	2.00 mtr	MR
	g. Number of Door class Room	1	1	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	12	12	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

(Signature)


6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 lit/min	450 lit/min	MR
	➤ Head of the pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 ltr	6,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR

N/12


16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, The Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2019/NDZ/2052 Dt. 25/10/19 renewal under D.O.E. Circular No. 262-362 Dated 17/01/2005 is recommended.


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : D.O. (East Division)

By: CFO (NDZ) F.T. please.



 18/11/2022


DO(ED) Sir,

F.T. is added for signature pl.

By: CFO (NDZ)

F.P. wing


 29/11/2022


 29/11/2022