



15/11/2022

C/62

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2022/ 341

Dated: 02/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Breath (A unit of MSVY Group), located at Plot No. 3C, 2nd floor & 3rd floor, NWA, Club Road, Punjabi Bagh, New Delhi-110026, in a Building comprised of Basement + stilt + Ground + 03 Upper Floors, Owned/Occupied by M/s. Breath (A unit of MSVY Group), was issued FSC Vide Letter No. F6/DFS/MS/WZ/2019/2336 dated 18/12/2019. The premises was re - inspected by the officer concerned of this department on 18/11/2022 in the presence of Sh. Yash Singhal (Partners), have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the said building is fit for occupancy class "Assembly" Group D (Second & Third Floor only) with effect from 02/12/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions printed Overleaf.

Issued on ... 02/12/2022 ... at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Owner/occupier M/s M/s Breath (A unit of MSVY Group), located at Plot No. 3C, 2nd floor & 3rd floor, NWA, Club Road, Punjabi Bagh, New Delhi-110026. (Online Id 2022103019539)
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in).
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest_zone@gmail.com)

30/11/2022



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management/occupier.
3. The trained staff should be available round the clock.
4. Basement shall be used as per building bye laws.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : M/s Breath (A unit of MSVY Group), located at Plot No. 3C, 2nd floor & 3rd floor, NWA, Club Road, Punjabi Bagh, New Delhi-110026.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MN/WZ/2019/2336 dated 18/12/2019
5. Fire Safety directives letter No : Nil
6. Date of inspection : 18/11/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Mr. Yash Singhal (Partners)
9. Year of Construction : 2018 (As per prev. insp. report dated 10/12/2019)
10. Applicant's letter No. : Online Application 2022103019539 dated - 30/10/2022

* **The Said Restaurant is running at 2nd & 3rd floor in a building comprised of Basement, Stilt, Ground + 03 Upper floors.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/ As per prev. insp. report dated 10/12/2019	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mtr	Provided	MR
	• Gate width	NA	On Main Road	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	02 Provided	NA
	b. Width of staircases			
	• Upper Floors	2 mtr & 1.5 mtr	1 x 1.5m, 1x2m & 96cm	MR
	• Basements	NA	Other Property	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2mts & 1.5mts	2 nd F=2m, 1.5m & 1.12m 3 rd F = 213cm, 1.5m & 81cm	MR
3	Compartmentation.			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	NR	NR	NR
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	• Basement	NR	NR	NR
	• Upper Floor	NR	Provided	NR
	• Sprinkler above false ceiling	NR	NR	NR
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	70 MH	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 MH	Provided	MR
	➤ Standby Pump out put	2280lpm	Provided	MR
	➤ Standby Pump Head	70 MH	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	2 x 450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	32000 ltr provided	MR
15	Exit Signage.	Required	Provided	MR

24

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NR	NR	NR
	• Pressurization of Lift lobby	NR	NR	NR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Do (west)~~

~~Signature~~
21/11/2022

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

385/ADO/410
21/11/2022

D.O. (WEST) 752
DATED: 24/11/2022

~~Defo (w2)~~
24/11/2022

~~Signature~~
28/11/2022

~~ADO (MN)~~

Sir, F. T is put up for your kind personal & signature please.

~~Signature~~
30/11/2022

~~Dy CRO (w2)~~

~~Signature~~
21/11/2022

~~ADO (MN)~~