

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/2022/SZ/

543

Dated: 05/12/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Pushpawati Singhanian Research Institute, (PSRI Hospital), Press Enclave Marg, Sheikh Sarai-II, New Delhi-110017 comprised of Basement, ground plus five upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Hospital/2020/SZ/115 dated 26/02/2020. The premise was re-inspected by officers concerned of this department on 19/11/2022 in the presence of Mr. Devashish Kole (Chief Engineer) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-C Institutional (Hospital)** with effect from 05/12/2022 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 05/12/2022 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE


Copy to: -

1. M/s Pushpawati Singhanian Research Institute, (PSRI Hospital), Press Enclave Marg, Sheikh Sarai-II, New Delhi-110017
2. The Executive Engg. (Bldg) MCD, Green Park, Aurobindo Marg, New Delhi 110016.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

M/26




INSPECTION REPORT

1. Name & address of the building : M/s Pushpawati Singhania Research Institute, (PSRI Hospital), Press Enclave Marg, Sheikh Sarai-II, New Delhi-110017
2. Type of Occupancy : Class-C "Institutional (Hospital)"
3. Comprised of : Basement Ground plus Five Upper Floors
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/Hospital/2020/SZ/115 dated 26/02/2020
6. Fire Safety directives letter No : F6/DFS/MS/95/Hospital/641 dated 22/05/95
7. Date of inspection : 19/11/2022
8. Name of Inspecting Officer : DO (SD) & ADO (BCP)
9. Name and designation of officers
From the building side : Mr. Devashish Kole (Chief Engineer)
10. Year of Construction : -Nil
11. Applicant's letter No. : Outdoor diary no. 7492, dated 01/11/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per old Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p align="center">9m 5m 6m</p>	<p align="center">9m 5m 6m</p>	<p align="center">MR MR MR</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p align="center">2 No's</p>	<p align="center">2(GF to 5th Floor) +1 (GF to 2nd Floor)</p>	<p align="center">MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p align="center">2 No's</p>	<p align="center">1 + 1 ramp</p>	<p align="center">MR (Old Case)</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p align="center">2m & 1.025m</p>	<p align="center">2, 1.05m + 2m</p>	<p align="center">MR</p>
	d. No. of continuous staircases to terrace			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p align="center">2m & 1.025m</p>	<p align="center">2m + 2.5m ramp</p>	<p align="center">MR (Old Case)</p>
	e. Width of Corridor			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p align="center">Required</p>	<p align="center">Provided</p>	<p align="center">MR</p>
	f. Door Size			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p align="center">-NA-</p>	<p align="center">-NA-</p>	<p align="center">-NA-</p>
		<p align="center">One</p>	<p align="center">One</p>	<p align="center">MR</p>
		<p align="center">-NA-</p>	<p align="center">-NA-</p>	<p align="center">-NA-</p>
		<p align="center">-NA-</p>	<p align="center">-NA-</p>	<p align="center">-NA-</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p align="center">Required</p>	<p align="center">Provided</p>	<p align="center">MR</p>
		<p align="center">Required</p>	<p align="center">Provided</p>	<p align="center">MR</p>
		<p align="center">-NA-</p>	<p align="center">-NA-</p>	<p align="center">-NA-</p>
		<p align="center">-NA-</p>	<p align="center">-NA-</p>	<p align="center">-NA-</p>
		<p align="center">Required</p>	<p align="center">Provided</p>	<p align="center">MR</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	<p align="center">30 a/c per hour</p>	<p align="center">Provided</p>	<p align="center">MR</p>
	<ul style="list-style-type: none"> • Upper floors 	<p align="center">12 a/c per hour</p>	<p align="center">Provided</p>	<p align="center">MR</p>
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<p align="center">80 No's ISI</p>	<p align="center">95 No's ABC-65 No's W. CO₂/CO₂ - 30 No's</p>	<p align="center">MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<p align="center">Two 30m 5mm</p>	<p align="center">Provided Provided Provided</p>	<p align="center">MR MR MR</p>
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	<p align="center">Smoke & Heat Required -NA- Required Required</p>	<p align="center">Provided Ground Floor -NA- Provided All floors</p>	<p align="center">MR MR -NA- MR MR</p>
8.	MOEFA	<p align="center">Required</p>	<p align="center">Provided</p>	<p align="center">MR</p>

M/27



9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150mm	150mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	Two	Two	MR
	<ul style="list-style-type: none"> Hose Box 	Two	Two	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	Required	6 No's	MR
	<ul style="list-style-type: none"> Hose Box 	Required	6 No's	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2850LPM	2850LPM	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	90m	90m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	One	One	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	90m	90m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2850LPM	2850LPM	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	90m	90m	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of the pump 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Power Supply 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 			
	<ul style="list-style-type: none"> ➤ Draw-off connection 	2,00,000 Lts	2,00,000 Lts	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 Lts.	20,000 Lts.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Flow Switch Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Battery backup 	Required	Provided	MR
	<ul style="list-style-type: none"> Building Floor Plans 	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	CO ₂ Extinguisher for LT & HT Panels	MR (Old Case)

m

N/88



The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Hospital/2020/SZ/115 dated 26/02/2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature.

manish

Rajesh Kumar

Signature of the Inspection Officer
Name: Sh. Manoj Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DY. CFO (SZ)

[Signature]

[Signature]
22/11

- CF/O -
1. FSC is valid up to 25.2.2023.
 2. You have not recommending for renewal before 3(three) months.
 3. Please clarify.

Dy CFO (SZ)
DO (South)

[Signature]

[Signature]
23/11/2021

manish
28/11

Sir, as per DFS Act & Rule 37(i) FSC should be applied before 6 months.

Accordingly application for renewal was accepted & recommended for FSC renewal pl.

Submitted pl

Dy CFO (SZ)

[Signature]

manish
28/11