

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/BNQT/WZ/2022/ 65

Dated: 05/12/22

FIRE SAFETY CERTIFICATE

Certified that the M/s. Ananda Banquet Hall located at ground floor only 33/33A, Shivaji Marg, Najafgarh Road, New Delhi-110015, comprised of Basement, Ground plus 02 upper floors, was granted fire safety certificate by this department vide letter no. F6/DFS/MS/WZ/2018/2737 dated 19/12/2018 to M/s. Chandelier (A unit of Vedic Hospitality) for Ground floor only. The banquet hall was re-inspected by the officer concerned of this department on 14-11-2022 in the presence of Sh. Ishant Harjai (Owner) and found that the banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" Group D (for Ground floor only) with effect from 05/12/22 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 conditions printed overleaf.

Issued on 05/12/22 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The owner/ Occupier, M/s. Ananda Banquet Hall located at Ground floor, 33/33A, Shivaji Marg, Najafgarh Road, New Delhi-110015. (Online Application ID No. 2022041707295 dated 03/08/2022 & 2022082216412 dated 09/11/2022)
2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027. dhowestzone@gmail.com



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **This NOC is valid for Ground floor only.**

14-40

INSPECTION REPORT

1. Name & address of the building	Ananda Banquets, located at GF, FF & SF, Plot no. 33/33A, Shivaji Marg, Najafgarh Road, New Delhi-110015.
2. Type of Occupancy	Banquet Hall (Assembly)
3. Type of Case	Renewal (Earlier Issued FSC in the name of M/s Chandelier Banquet)
4. Details of previous NOC	F6/DFS/MS/WZ/2018/2137 dated 19/12/2018 for GF only
5. Fire Safety directives letter No	F6/DFS/MS/BP/2011/839 dated 09/05/2011
6. Date of inspection	14/11/2022
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ishant Harjai (Owner)
9. Year of Construction	2011 (As per Prev. Insp. report dated 02/12/2018)
10. Applicant's letter No.	Online Application ID No. 2022041707295 dated 03/08/2022.& 2022082216412 dated 09/11/2022

The said Banquet Hall is running at Ground floor only in a Building comprised of Basement + Ground + 02 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/ As per prev. Insp. Rep. dated.- 19/10/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width 	12 m	Provided	MR
	<ul style="list-style-type: none"> Gate width 	5 m	On Main Road	MR
	<ul style="list-style-type: none"> Width of internal road 	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2m & 1m	2x175m & 1x2m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	NA	Provided	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	08 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	CO ₂ , ABC type	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR

11-11			
6	First-Aid Hose Reels.		
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	Provided
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	Provided
7	Automatic fire detection and alarming system.		
	<ul style="list-style-type: none"> Type of detectors 	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA
8	MOEFA	Required	Provided
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	<ul style="list-style-type: none"> Basement 	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	Provided
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA
11	Internal Hydrants		
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided
	<ul style="list-style-type: none"> Hose Box 	01	Provided
12	Yard Hydrants.		
	<ul style="list-style-type: none"> Total number of hydrants 	NR	NR
	<ul style="list-style-type: none"> Hose Box 	NR	NR
13	Pumping Arrangements.		
	<ul style="list-style-type: none"> Ground Level 	NA	NA
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA
	<ul style="list-style-type: none"> Terrace level 		
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 lpm	Provided
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	Provided
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided
14	Captive Water Storage for fire fighting.		
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs	Provided
		Required	Provided
15	Exit Signage.		

M 42

Provision of Lifts.

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked & found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/WZ/2018/2737 dated 19/12/2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

Do (west)

[Signature]
18/11/2022
Signature of the Inspecting Officer
Sarabjeet Singh
ADO (Moti Nagar)

[Signature]
18/11/2022

DCS (wz)

[Signature]
18/11/2022

D.O. (WEST) FSY
18/11/2022

F.T
[Signature]
M-N
[Signature]
Dy C.R. (wz)

Sir, F.T is put up for your perusal & Signature Mess...

[Signature]

uploaded
06/12/22