

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2022/ 1295

Dated: 02/12/2022

FIRE SAFETY CERTIFICATE

Certified that the building of Abhinav Global School (Vijay Shri Educational Cultural & Welfare Society) Located at Sector 13, Dwarka, Phase – II, New Delhi running at Stilt+ Ground + 2 UFs in a building comprised of B + Stilt + Ground + 3 UFs was issued Fire Safety Certificate vide letter No: F6/DFS/MS/School/2014/SZ/852, dated 10/07/2014. The premises was re inspected by the officer concerned of this department on 21/11 /2022 in the presence of Sh. Kotilya Bansal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" Group B (Stilt + Ground + 2 UFs) with effect from 02/12/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/12/2022 at New Delhi by.

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Abhinav Global School (Vijay Shri Educational Cultural & Welfare Society) Located at Sector 13, Dwarka, Phase – II, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. **Basement & 3rd floor shall strictly not be used for any purpose.**
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Abhinav Global School (Vijay Shri Educational Cultural & Welfare Society) Located at Sector 13, Dwarka, Phase – II, New Delhi.
2. Type of Occupancy : Educational (Running at Stilt+ Ground + 2 UFs in a building comprised of B + Stilt + Ground + 03 UFs)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/School/2014/SZ/852. dated 10/07/14
5. Fire Safety directives Le. No. : F6/DFS/MS/BP/2013/139, dated 27/06/2013
6. Date of inspection : 21/11/2022
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Kotilya Bansal
9. Year of Construction : 2015
10. Applicant's letter No. : Email dated 29/11/2022 & 17/11/2022

Total Area = 8094 sqm.
Covered Area = 7395 sqm
Class rooms = 54
No. of students = 750

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/BC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	06 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	Provided	MR
	• Basements	NA	Not in use	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Provided (Old case)	MR (being old case)
	• Basements	NA	Not in use	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	03 Nos.	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

(Handwritten signature)

21/14

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	38 Nos.	Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	1620 lpm	Provided	MR
	➤ Head of the pump	55 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

415

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	DG set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location.	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the **FSC** issued vide letter F6/DFS/MS/School/2014/SZ/852. dated 10/07/2014 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *AO/DW/K*

29/11/22
21/11/22
22/11
23/11/22
22/11/2022
Director
g-funk
16/11
21/11/22
PTO. 23/11/22