



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/ WZ/Hospital/2022/ 552

Dated: 07/12/2022

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Kids Clinic India Ltd (Cloudnine Hospital)** at Plot No. 1, Club Road, Punjabi Bagh West, New Delhi-110026 building comprised of Basement, Ground & Three Upper Floors Owned/Occupied by **M/s. Kids Clinic India** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 07.11.2022 in the presence of Dr. Shashank Sharma and Sh. Naveen Yadav of the hospital and that the building is fit for occupancy class- Institutional "(Hospital building)" with effect from... 07/12/2022 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.subject to condition as mentioned below. conditions printed overleaf.

Issued on 07/12/2022 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to :-

1. The Authorized Signatory, M/s. Kids Clinic India Ltd (Cloudnine Hospital) at Plot No. 1, Club Road, Punjabi Bagh West, New Delhi-110026
2. Dr. Nitin Kumar, Directorate General of Health Service, Nursing Home Cell, S-1, School Block, Shakarpur, Delhi-110092

o/c 
01/12/2022



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **If 4th floor re-erected/re-constructed and any use this Fire Safety Certificate shall be null and void.**

INSPECTION REPORT

1	Name & address of the building	Kids Clinic India Pvt. Ltd (Cloudnine Hospital), Plot No 1, Club Road , Punjabi Bagh West, New Delhi-110026		
2	Type of Occupancy	Institutional building "G" (Hospital)		
3	Building Comprised of	Basement, Ground plus Three upper floors		
4	Type of case	New		
5	Details of previous NOC	Nil		
6	Fire safety directives letter No	F6/DFS/MS/BP/Hospital/2022/287 Dated 04 02 2022		
7	Date of inspection	07.11.2022		
8	Name of the inspecting Officers	Dharampal Bhardwaj DCFO (WZ), M.K. Chattopadhyay DO (W) & Sarbjit Singh ADO (MN)		
9	Name and designation of officers from the building side	Dr. Shashank Sharma (Zonal Manager)		
10	Year of construction	2021		
11	Applicant's letter No	Outdoor diary dated 01 11 2022		
Minimum Standards on fire prevention and fire safety U/R 33				
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	15Mtr	Provided	MR
	2) Gate width	5 Mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1 Upper floors	2 Nos	3 Nos. Provided	MR
	2 basements	2 Stairs	Provided	MR
	b. Width of staircase			
	1 Upper floors	2 & 1.5 Mtrs	2, 1.5 & 1.00 Mtrs Provided	MR
	2 basements	2 & 1.5 Mtr	2 & 1.5 Mtrs Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	Two	Provided	MR
	e. Width of corridor	2.4 Mtr	Provided	MR
	f. Door size	1.25 & 2 Mtr	1.25 Mtr - (Patient Rooms) & 2 Mtr (ICU , OT) Provided	MR
3	Compartmentation.			
	1 Fire check door	Required	Provided	MR
	2 Sealing of electrical shafts	Required	Provided	MR
	3 Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	12 a/c per hour	Provided	MR
	upper floors		Provided	MR
5	Fire Extinguishers			
	total numbers		20 Nos. Provided	MR
	Types		ABC, CO2 , Water Co2	MR
	ISI marking	ISI	Provided	MR

INSPECTION REPORT

6	First-Aid Hose Reels.			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Smoke & Heat	Provided	MR
	location of Main Panel	Required	Basement	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	Required	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	2 Nos	Provided	MR
	house box	2 Nos	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a Discharge of main Pump	2280 LPM	Provided	MR
	b Head of main pump	80 Mtr	Provided	MR
	c Number of main pumps	One	Provided	MR
	d jockey pump out put	180 LPM	Provided	MR
	e jockey pump head	80 Mtr	Provided	MR
	f Standby Pump output	2280 LPM	Provided	MR
	g Stanby Pump head	80 Mtr	Provided	MR
	h Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a Discharge of pump	N/A	N/A	N/A
	b head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	1,50,000 ltr	1,50,000 Ltr Provided	MR (Undertaking submit)
	a Draw-off connection	Required	Provided	MR
	b fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided	MR
	b pressurization of lift lobby	N/A	N/A	N/A
	c communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.		N/A	
	total area			
	location			




INSPECTION REPORT

19	Fire control room			
	a Detector system Panel	N/A	Provided	N/A
	b Flow switch Panel	N/A	Provided	N/A
	c PA system Panel	N/A	Provided	N/A
	d Batter backup	N/A	Provided	N/A
20	e Building floor plans	N/A	Provided	N/A
	Special Fire Protection systems for protection of special risks, if any	CO2, Automatic suppression system	Provided	MR


Note - The hospital management has submitted an undertaking and photograph for removal of 4th floor. If 4th floor re-erected/re-constructed this Fire Safety Certificate shall be null and void.
The fire protection systems provided in the building were checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for your approval and signature please


		
Signature of the inspecting officer	Signature of the inspecting officer	Signature of the inspecting officer


Name Dharampal Bhardwaj	Name - M K Chattopadhyay	Name Sarbjeet Singh
Designation DCFO (WZ)	Designation DO (West)	Designation ADO (MN)

CAO 
23/11/2022


Director 
23/11/22


F T DC

DD / JMD 
01/12/2022

ADO (MN) 

Sir, F.T is put up for your kind personal & signature please.


01/12/2022

Director 
2/12/22

M K S